



Bengaluru Electricity Supply Company Limited
(Wholly Owned Government of Karnataka Undertaking)

BESCOM GSTN No: 29AACCB1412G1Z5

New Connection Application form

Application No.: 1113108250024 Sub Application No.:
11131082500240001

Sub Division:
DABASPETE

Application Details			
Applicant Name	M/S ASSETZ INDUSTRIAL PARKS PVT LTD	Spouse/Father Name	Rep Somasundaram Thiruppathi
Perm Address	BLOCK-4,DABASPETE 5TH PHASE, BILLINAKOTE, AVVERAHALLI KIADB INDL AREA,SOMPURA(H),NEL AMANGALA(T)	Corresp Address	BLOCK-4,DABASPETE 5TH PHASE, AVVERAHALLI KIADB INDL AREA,SOMPURA(H),NEL AMANGALA(T), BILLINAKOTE
Mobile	9880713403	Email Id	venkatesh@sequentglobalinc.com
Pan No	AANCA4586D	Adhar No	269802932843
Application Date	12-AUG-2025	Tariff	HT2A
Location Details			
District	BANGALORE RURAL	Taluk	NELMANGALA
GP	HONNENAHALLY	Village	AVVERAHALLI INDL AREA
Pincode	0		
Additional Details			
Premesis Located in	KIADB	Site Dimension (Sq m)	24911
Builtup Area (Sq Mtrs)	23252	Phase	3-PHASE
License Details			
LEC Name	SEQUENT GLOBAL INC	LEC License Number	SGL00257BNU
LEC License Upto	31-08-2026		
Supervisor Name	RANGANATHA B N	Supervisor Permit No	1GR129605BNG
Supervisorm LEC Valid Upto	31-12-2025		
Power Supply Details			
Application Type	Permanent Service	Voltage Class	11KV
Purpose	HT Industrail	Requested Load (KVA)	1950
Registration Fee			



ಬೆಂಗಳೂರು ವಿದ್ಯುತ್ ಸರಬರಾಜು ಕಂಪನಿ ನಿಯಮಿತ
BANGALORE ELECTRICITY SUPPLY COMPANY LIMITED

No: CEBRAZ/SEO/AEE-2/2025-26 /

44A1-85

Email ID: cebraz.work@gmail.com

E-mail: cebraz@bescom.co.in

Ph No. 080-23500117

Encl:

Office of the

Chief Engineer Ele,

Bangalore Rural Area Zone,

No.1- 4, IT Park, 5th Floor, KSIIDC Building,

Rajajinagar Industrial Estate, Rajajinagar,

Bengaluru- 560 044,

Date: 21 AUG 2025

M/s Assetz India Parks Pvt Ltd ,

E- khatha No. 150300700300220185,

488/Block -4, Dabasapete

5th phase Industrial area,

Billanakote village,

Dabasapete

Sir,

Sub: Arranging HT power supply to an extent of **1950 kVA** in favour of **M/s Assetz India Parks Pvt Ltd** , rep by Sri Somasundaram Thiruppathi , E- khatha No. 150300700300220185, 488/Block -4, Dabasapete 5th phase Industrial area, Billanakote village, Dabasapete sub-division, Nelamangala division

Ref: SEE, BRC circle Lr No. SEE/EE(O)/AEE(O)/F-2(B)/2025-26/2969-72 dated 21-08-2025

With reference to the above, as per the recommendation of the Superintending Engineer Ele., BRC circle under reference, power sanction is hereby issued for arranging HT power supply to an extent of **1950 kVA** in favour of **M/s Assetz India Parks Pvt Ltd** , rep by Sri Somasundaram Thiruppathi , E- khatha No. 150300700300220185, 488/Block -4, Dabasapete 5th phase Industrial area, Billanakote village, Sompura Hobli, Dabasapete sub-division, Nelamangala division under HT 2(a) tariff.

The power supply shall be arranged from the following source:

Regular source:

Line: Existing AF-3 Sangavi feeder with 3*400 sqmm XLPE UG cable

Peak load: 192 Amps

MUSS: 66/11 kV Avverahalli MUSS

Peak load: 25.80 MW

Transformer capacity : 2*20 MVA

Bank: 1

Peak load: 11.70 MW

21.8.2025

The following works are proposed under self execution:

- a) Tapping of existing 11 kV line using 3*400 sqmm XLPE UG cable to a distance of 700 mtrs (by providing 02 Nos of 11 mtrs long spun pole and 2 Nos of 400 Amps GOS .
- b) Providing 01 No of intermediate OD
- c) Extension of 11 Kv line using 3*400 sqmm XLPE UG cable to a distance of 30 mtrs (double run) from proposed RMU outside the proposed HT metering cubicle
- d) Providing 01 No of 11 kV HT metering cubicle

Alternate source:

Line: Existing AF-5 feeder with 3*400 sqmm XLPE UG cable

Peak load: 92 Amps

MUSS: 66/11 kV Avverahalli MUSS

Peak load: 25.80 MW

Transformer capacity : 2*20 MVA

Bank: 1

Peak load: 11.70 MW

The following works are proposed under self execution:

- a) Tapping of existing 11 kV line using 3*400 sqmm XLPE UG cable to a distance of 1200 mtrs
- b) Providing 02 Nos of intermediate ODs

The total cost of the estimate is **Rs. 1,10,22,621/- (Rupees one crore ten lakh twenty two thousand six hundred and twenty one only)**

1. You have to pay the following amounts in the form of DD in favour of Asst. Executive Engineer Ele., BESCOM, **Dabaspete sub-division** within 90 days from the date of this power sanction.

- a) **Rs. 5,43,631/-** (Rupees five lakh forty three thousand six hundred and thirty one only) towards 5% supervision charges of **Rs. 1,08,72,621/-** (excluding DEI)
- b) **Rs. 40,000/-** (Rupees forty thousand only) towards cable testing charges
- c) **Rs. 12,240/-** (Rupees twelve thousand two hundred and forty only) towards OD testing charges
- d) **Rs. 4080/-** (Rupees four thousand eighty only) towards HT metering cubicle testing charges
- e) **Rs. 39,19,500/-** (Rupees thirty nine lakh nineteen thousand five hundred only) towards **2 MMD under HT 2 (a) tariff**

2. Power supply shall be arranged on HT basis.

3. Metering shall be as per the BESCOM standards and norms.

4. In future, if the total load requirement exceeds 7500 kVA then the applicant/developer shall establish 66/11 KV substation at their own cost in the above premises under self-execution and avail power supply on 66 KV EHT basis as per KERC regulations.

5. 11 KV system shall be as per KPTCL/ BESCOM standard practices.