



**GOVERNMENT OF KARNATAKA  
(Electrical Inspectorate)**



Scan the above QR Code  
for verifying the authenticity of the Approval

Ack No : EI000110906126

Date : 08/12/2025

GSC No : EN0010000385788

Deputy Electrical Inspector,  
O/o Deputy Chief Electrical Inspector,  
Bengaluru Additional North,  
No. A67a, 3rd Floor,  
1st cross, Industrial Estate,  
Rajajinagara,  
Bengaluru - 560 010  
Phone No :08023354509

To

MS DIVINE CLOTHING  
SY. NO. 24/07, MARUTHI FARM,  
DOMBARAHALLI VILLAGE NELAMANGALA, BENGALURU RURAL(District), NELAMANGALA(Taluk)  
Karnataka, India-562123

Sir,

**Sub :** Approval of electrical installation pertaining to 1x100KVA, 11KV/433V Transformer center for arranging LT power supply to an extent of 100HP for Industrial Purpose **MS DIVINE CLOTHING SY. NO. 24/07, MARUTHI FARM,, DOMBARAHALLI VILLAGE, DASANAPURA VILLAGE,, NELAMANGALA, BANGALORE ADDL NORTH(District), BANGALORE ADDL NORTH(Taluk) - 562123**

**Drawing Ref No : EI000110902816**

**Ref :** 1. Ltr. No.:EEE/AEE(O)/NEL/AET/2025-26/343-44 Dated: 05.04.2025-from the Executive Engineer (Ele.), C, O & M division, BESCO, Nelamangala - for power sanction.  
2.SETC-Drg-553/2025-26 Dated:02.12.2025.

\*\*\*\*\*

With reference to the above, approval is hereby granted for energizing the electrical installation at [ **MS DIVINE CLOTHING with SY. NO. 24/07, MARUTHI FARM,, DOMBARAHALLI VILLAGE, DASANAPURA VILLAGE,, NELAMANGALA, BANGALORE ADDL NORTH, BANGALORE ADDL NORTH - 562123** ] under Regulation No. [ 45 ] of Central Electricity Authority (Measures relating to Safety and Electric Supply) Regulation, 2023 as per details enclosed.

This approval is strictly subject to your full compliance with the relevant provisions of the Central Electricity Authority (Measures relating to Safety and Electric Supply) Regulation, 2023 (as amended to date) in every respect.

**Note :**

SETC-449/2025-26

**Conditions :**

1. As per Regulation No: 48(5) and 48(6) required records shall be maintained.
2. As per Regulation No: 48(7) the installation shall be maintained and operated in a condition free from danger.
3. As per Regulation No: 3 designated person(s) shall operate and carryout the work on electrical lines and apparatus.

Inspection fee of **Rs. 10,600/- (IN WORDS) Ten Thousand Six Hundred** onlypaid vide K2 Challan Ref. No: **EL1225004300001977** dated **04/12/2025**



**GOVERNMENT OF KARNATAKA  
(Electrical Inspectorate)**



Scan the above QR Code  
for verifying the authenticity of the Approval

**Details of Equipments :**

- 1.HT Cable: Rabbit ACSR Conductor - from Tapping point to DP structure.
- 2.HT Switchgear: 200A GOS and HG Fuse unit & LA s on Double Pole Structure.
- 3.Transformer: Make: Shree Vijay controls, 1x100KVA, 11KV/433V, 5.25/133.33A, SI No: SVC/100/L2/862.
- 4.LT Cable: 1Rx3.5Cx150Sqmm A2XFY UG Cable
- 5.LT Switchgear: 160A, MCCB at Transformer centre.
6. Sanctioned Load: 100HP.

Yours faithfully,



**Digitally Signed by : PUTTASWAMY M**  
**Deputy Electrical Inspector**  
**Bangalore Additional North**  
**Signed Date : 08/12/2025**

**Note: This is a Digitally Signed Certificate and Does not require manual signature.**

**Please, Verify authenticity of this certificate by visiting [www.ksei.gov.in](http://www.ksei.gov.in) and entering certificate number in Third party verification.**

**Copy To : SINCHANA ELECTRICALS**

# 411, , 12th main 4th cross , MANJUNATHANAGAR, , NEAR PARLGE , BANGALORE , BANGALORE NORTH , 560073  
**License No: 1CL07048BNU Valid Upto: 30/09/2029**