

Application Details

Applicant Name	BHAVYA K N	Father/Husband Name	NARASIMHAMURTHY
Perm Address	SIDDANAHALLY	Corresp Address	SIDDANAHALLY
Mobile	7026418131	Email Id	
Application Date	10-NOV-2025		

Location Details

Taluk	MADHUGIRI	GP	GONDIHALLI
Village	SIDDANAHALLY	Pincode	572175

Additional Details

Premises Located in	Village Panchayat / Gram Panchayat	Site Dimension (Sq m)	0
---------------------	------------------------------------	-----------------------	---

Document Details

Proof Type	Document Type	Proof ID NO
COMP_CERTIFICATE	Completion-Cum test report along with wiring diagram	12079
IDENTITY_PROOF	Aadhar Card	823638297502
PROOF_OWNERSHIP	Katha Certificate	PR0022117021579

Registration Fees Details

Application ID	Sub Application No	Types of Charges	Amount in Rs.	CGST(9%)	SGST(9%)	Total Amount
2216211250008	22162112500080001	Initial Security Deposit~48.1017	820	0	0	820
2216211250008	22162112500080001	Registration Fees~61.9067	50	0	0	50
Total :			870	0	0	870

Total Amount Payable: Rs. 870

L T New Connection Details (Multiple)

Application ID	Sub Application NO	Power Supply Required For	Nature of Business	Requested Load KW/HP	Tariff	Phase	Billing Type	Source Type
2216211250008	22162112500080001	DOMESTIC	Residential House	1.0 KW/0.0 HP	LT1-Rural	1-PHASE	POST PAID	SMART METER

NOTE: Registration Fees is to be Paid within 30 days of Application Registration



HPL ELECTRIC & POWER LTD.

ROUTINE TEST REPORT

1 Phase, 2 Wire, SP 5-30A-DLMS-BESCOM-M.102(UTL)/56 RATING 5-30 AMP, 240 Voltage OF Class 1

REFERENCE STANDARD DETAILS

MODEL 2330E
SR NO. 1201110681
CLASS 0.05
CAL DUE DATE 12-Jul-2026

METER NO. 70353232

REF. STND. IS:13779

MODEL SPEM 46

ELECTRICAL INSPECTION

Voltage Test: 4 KV	Pass	Starting Current test(at 0.2% of Ib UPF)	Pass
Insulation Resistance test	Pass	No Load Condition test(at 115% of V ref.)	Pass

PERCENTAGE OF LIMITS OF ERROR - ALL ERRORS ARE IN %

UPF				0.50 PF (LAG)				0.80 PF (LEAD)			
Ib	10% Ib	Ib	I _{max}	10% Ib	20% Ib	Ib	I _{max}	10% Ib	20% Ib	Ib	I _{max}
22	-0.10	-0.08	-0.02	0.15	0.21	0.14	0.25	-0.23	-0.16	-0.13	-0.03

Note:- This is system generated document and does not require signature

Date : 10-Mar-2025