



ಬೆಂಗಳೂರು ವಿದ್ಯುತ್ ಸರಬರಾಜು ಕಂಪನಿ ನಿಯಮಿತ

(ಸರ್ವೋಚ್ಚ ನಗರೀಕರಣ ರಾಜ್ಯ ಸರ್ಕಾರದ ಸ್ವಾಮ್ಯಕ್ಕೆ ಒಳಪಟ್ಟಿದೆ)

ಅಂಶ: ಅನು(ವಿ)/ರಾಜ್ಯ/ಕಾನೂ(ಕ)/ಸಂಖ್ಯೆ/2025-26/

ಸಂಖ್ಯೆ

6563-65

Email: sermgc.work@gmail.com

Phone No. 080-28488780

IESCOM GST NO: 29AACCB1412G1Z5

ಅಧಿಕೃತ ಇಂಜಿನಿಯರ್(ವಿ)ರವರ ಕಛೇರಿ,
ಎಂ. 28, 28 & 28, ಬೆಂಗಳೂರು, ರಾಮನಗರ ಪುರ,
ಬೆಂ.285, ಎಲ್.ಪಿ. ಆರ್.ಡ್,
ಜಿಗನಿ ಹಬ್ಬಲಿ ಲೇಔಟ್, 2ನೇ ಹಂತ,
ವೆಂಕಟೇಶ್ವರ, 100 ಅಡಿ ಡಬಲ್ ಡೋರ್,
ಶಿಶು ಅಪಾರ್ಟ್‌ಮೆಂಟ್ ಹತ್ತಿರ,
ಕೋಡಿ ಉಪವಿಭಾಗ, ಬೆಂಗಳೂರು-560060.

25 NOV 2025

To
Sri. Rajesh N S/o Narayana Reddy,
Sy No. 02,
Koppa Village,
Jigani Hobli, Anekal Taluk,
Bangalore Urban District,
Jigani Sub-Division.

ಅಧಿಕ ವಿದ್ಯುತ್ ಭಾರ

ಪ್ರಾಪ್ತಿ.

ವಿಷಯ: ನಿಮ್ಮ ಕಾಲಿ ಬಯಸುವುದಿ ಕಟ್ಟಡಕ್ಕೆ ಅಧಿಕ 70 HP (ಹಾಲಿ 23 ಕಿ.ವ್ಯಾ+ 30 HP + ಅಧಿಕ 70 HP ; ಒಟ್ಟು 23 ಕಿ.ವ್ಯಾ+100 HP) ಅಧಿಕ ವಿದ್ಯುತ್ ಭಾರ (ಕ್ಯೂರಿಟಾ) ಉದ್ದೇಶಕ್ಕೆ ವಿದ್ಯುತ್ ಸಂಪರ್ಕ ಕಲ್ಪಿಸುವ ಬಗ್ಗೆ.

ಉಲ್ಲೇಖ: ಅನು(ವಿ)/ಚಂದಾ /ಸಕಾನಿಇಂ(ಕ)/ಸಂಖ್ಯೆ(ತಾಂ)/2025-26/8914-15 ದಿ: 21.11.2025 ಚಂದಾಮರ ದಿಫಾಗ.

Application ID: 61324111250023

ನಿಮ್ಮ ಬಾಕಿವಿಲ್ಲದೆ ನೀವು ಕೋರಿರುವಂತೆ ಅಧಿಕ 70 HP (ಹಾಲಿ 23 ಕಿ.ವ್ಯಾ+ 30 HP + ಅಧಿಕ 70 HP ; ಒಟ್ಟು 23 ಕಿ.ವ್ಯಾ+100 HP) ವಿದ್ಯುತ್ ಭಾರವನ್ನು ಕೆ.ಇ.ಆರ್.ಸಿ ನಿರ್ಮಿತ 3.1.5ರ ಪ್ರಕಾರ ಈ ಕೆಳಗೆ ಸೂಚಿಸಿರುವ ಭರತುಗಳ ಮೇರೆಗೆ ಮಂಜೂರು ಮಾಡಲಾಗಿದೆ. ಈ ಮಂಜೂರಾತಿಯು ಈ ದಿನಾಂಕದಿಂದ 90 ದಿನಗಳವರೆಗೆ ಚಾಲ್ತಿಯಲ್ಲಿರುತ್ತದೆ. (ಹಾಲಿ 23 ಕಿ.ವ್ಯಾ+ 30 HP + ಅಧಿಕ 70 HP ; ಒಟ್ಟು 23 ಕಿ.ವ್ಯಾ+100 HP)

1. ಕಾವ್ರ ಕಾಲಿ ಕಟ್ಟಡದ ಕಟ್ಟಡದ ವಿನ್ಯಾಸ 1914 ಚ.ಮೀ, Ground Floor ಇರುತ್ತದೆ. ಹೊಸದಾಗಿ ನೀವು ಕೋರಿರುವ ಅಧಿಕ ವಿದ್ಯುತ್ ಪ್ರಮಾಣ 70 HP (ಕ್ಯೂರಿಟಾ)
2. ಸದರಿ ಸ್ಥಾವರಕ್ಕೆ ಕಾಲಿ ಇರುವ F-36 A Koppa Feeder, 220/66/11KV Jigani MUSS ಉಪಸ್ಥಾಪನೆಯಿಂದ ವಿದ್ಯುತ್ ಸರಬರಾಜು ಮಾಡಲಾಗುವುದು.
3. ಚಾಲ್ತಿಯಲ್ಲಿರುವ ಎಲ್.ಪಿ.-5 ಜಲಾಶಯ ನಿಮ್ಮ ಸ್ಥಾವರಕ್ಕೆ ಅನ್ವಯಿಸಲಾರದು.

Page 1 of 4

Applicant Name: Sri. Rajesh N S/o Narayana Reddy,

Application ID: 61324111250023

Sl No	particulars	Amount (in Rs.)	9 % CGST (in Rs.)	9% SGST (in Rs.)	Total Amount Rs.
1	2MMD:				
	a) 61 III* 01 Nos: Tariff LT-5 (37210) on Existing RR No. KP. 370(EX load 0.5KW +Add Load 61HP = Total Load 0.5KW+61HP)	37,210/-	0	0	37,210/-
	b) 09 III* 01 Nos: Tariff LT-5 (5490) on Existing RR No. KP. 371(EX load 0.5KW +Add Load 09HP = Total Load 0.5KW+09HP)	5,490/-	0	0	5,490/-
2	5% Supervision Charges on (Total Estimate Cost Rs. 94,347/-)	46,671/-	4200/-	4200/-	55,072/-
3	Transformer Testing fee	1,000/-	0	0	1,000/-
Total Amount (Rupees Ninety eight thousand Seven hundred and Seventy two only)					98,772/-

- As per BESCOM Circular No: BESCOM/ GM (QS&s) / DGM-3 / AGM-1 / BC-11 / 2024-25 / Cys-141, dt:03.12.2024 Dry type transformers required to create infrastructure shall be purchased from BESCOM approved Vendors only.
- If Dry type LBS/500KVA/CSS/transformer has been installed under self-execution, an under taking shall be furnished that the same shall be maintained for life time by the applicant.
- As per BESCOM order No: BESCOM/CGM(OP)/DGM (OP-1)/FY 2021-2022/CYS-17 Dt:17.05.2021. The sub divisional officers ensure the transformer quality and rating authorized test bench/ Divisional stores duly collecting transformer test certificate from the concerned MT division before servicing of installation.
- As per BESCOM Circular No: BESCOM/ GM (QS&s) / DGM-3 / AGM-1 / BC-11 / 2024-25 / Cys-15, dt:19.04.2024. All dry type transformers procured under Self-execution shall be go at the nearest test bench center and duly collecting transformer test certificate issue concerned MT division.
- As per BESCOM Circular vide ref: BESCOM/CGM(OP)/DGM(OP3)/2024-25/Cys-95 Dated 15.02.2025 & CYS-102 dated 25-03-2025, The power supply shall be arranged to the above said installations through "Smart Energy Meter in line with its capacity and quantum of load requirement in BESCOM jurisdiction".

Applicant Name: Sri. Rajesh N S/o Narayana Reddy,
Application ID: 61324111250023



Bengaluru Electricity Supply Company Limited
(Wholly Owned Government of Karnataka Undertaking)
BESCOM GSTN No: 29AACCB1412G1Z5

AEE/JIGANI (AET)

Office of the
Assistant Executive Engineer Ele.,
C,O&M, JIGANI Sub Division
BESCOM, JIGANI

To
RAJESH.N
KOPPAJIGANI—0

Sir/Madam

Sub : Arranging power supply to an extent of 0.50 KW 9 HP in favor of RAJESH.N KOPPAJIGANI—0 in JIGANI OMU, JIGANI

Ref: 1) Your application registration 61324111250022 dated 13-NOV-2025

2) AEE/JIGANI /AE(T) a/ 26-NOV-2025

With reference to your application dated 13-NOV-2025 . Requesting for arranging power supply to an extent of 0.50 KW 9 HP power installations in favor of RAJESH.N KOPPAJIGANI—0 in JIGANI OMU, JIGANI Sub division in hereby sanctioned subject to the following Conditions.

a. You are requested to pay the following charges by DD/cash (above 10000/- only DD will be Accepted) payable at the Office of C, O&M JIGANI sub-division and furnish the payment certificate for taking further action in this matter.

Application No	Sub Application No	Tariff	Requested Load	Account Head	Amount(Rs.)
61324111250022	2075453	LT5-Rural-INDUSTRIAL POWER - LT5A-RLB	0.50 KW/9.00HP	48.1037-48.1037 - ASD	4950
61324111250022	2075453	LT5-Rural-INDUSTRIAL POWER - LT5A-RLB	0.50 KW/9.00HP	48.1017-48.1017 - ISD	100
Total Amount in Rupees					5050

b. The power supply will be arranged at 0V .

c. The Tariff applicable to your installation will be LT5-Rural, or the Tariff in force From time to time.

d. You have to enter into an agreement with the BESCOM in the prescribed form.

e. Submit the Contractor's Completion-Cum-Test Report along with diagram in Duplicate.

f. You shall install LT metering panel approved by the BESCOM with suitable Capacity MCCB and/or ELCB.

g. Energy meter should be placed outside the premises at the height of 5ft from the ground level.

h. Amount through DD should be paid in the name AEE BESCOM JIGANI .

i. Intimation is valid up to 30 days from the date of issue.

In case the above requirements are not fulfilled within one month from the date of this communication, the sanction of power and registration will stand CANCELLED. The registration fee paid will be FOREFEITED. You are requested to contact the Asst. Ex. Engineer Ele., JIGANI Sub division, BESCOM for information and further needful.

Your's Faithfully,

Your's Faithfully,

Assistant Engineer (Technical),
JIGANI, BESCOM

Assistant Executive Engineer Ele.,
JIGANI, BESCOM

Copy to:

1. The Executive Engineer Ele. C, O&M CHANDAPURA Division, BESCOM.
2. The Asst. Executive Engineer Ele., C,O&M JIGANI Sub division, BESCOM.



Bengaluru Electricity Supply Company Limited
(Wholly Owned Government of Karnataka Undertaking)

BESCOM GSTN No: 29AACCB1412G125

AEE/JIGANI (AET)

Office of the
Assistant Executive Engineer Ele.,
C,O&M, JIGANI Sub Division
BESCOM, JIGANI

To
RAJESH.N
KOPPAJIGANI—0

Sir/Madam

Sub : Arranging power supply to an extent of **0.50 KW 61 HP** in favor of RAJESH.N KOPPAJIGANI—0 in JIGANI OMU, JIGANI

Ref: 1) Your application registration **61324111250023** dated **13-NOV-2025**

2) AEE/JIGANI /AE(T) a/ **26-NOV-2025**

With reference to your application dated **13-NOV-2025** . Requesting for arranging power supply to an extent of **0.50 KW 61 HP** power installations in favor of RAJESH.N KOPPAJIGANI—0 in JIGANI OMU, JIGANI Sub division in hereby sanctioned subject to the following Conditions.

a. You are requested to pay the following charges by DD/cash (above 10000/- only DD will be Accepted) payable at the Office of C, O&M JIGANI sub-division and furnish the payment certificate for taking further action in this matter.

Application No	Sub Application No	Tariff	Requested Load	Account Head	Amount(Rs.)
61324111250023	2075461	LT5-Rural-INDUSTRIAL POWER - LT5A-RLB	0.50 KW/61.00HP	61.9067-61.9067-TRANSFORMER TESTING FEE	1000
61324111250023	2075461	LT5-Rural-INDUSTRIAL POWER - LT5A-RLB	0.50 KW/61.00HP	61.9047-(WITH TAX) 5% Supervisory Charges(61.904)+CGST(46.9977)9%+SGST(46.9987)9%=(46671 + (46671*0.09) + (46671*0.09))	55071
61324111250023	2075461	LT5-Rural-INDUSTRIAL POWER - LT5A-RLB	0.50 KW/61.00HP	48.1037-48.1037 - ASD	36790
61324111250023	2075461	LT5-Rural-INDUSTRIAL POWER - LT5A-RLB	0.50 KW/61.00HP	48.1017-48.1017 - ISD	100
Total Amount in Rupees					92961

b. The power supply will be arranged at 0V .

c. The Tariff applicable to your installation will be LT5-Rural, or the Tariff in force From time to time.

d. You have to enter into an agreement with the BESCOM in the prescribed form.

e. Submit the Contractor's Completion-Cum-Test Report along with diagram in Duplicate.

f. You shall install LT metering panel approved by the BESCOM with suitable Capacity MCCB and/or ELCB.

g. Energy meter should be placed outside the premises at the height of 5ft from the ground level.

h. Amount through DD should be paid in the name AEE BESCOM JIGANI .

i. Intimation is valid up to 30 days from the date of issue.

In case the above requirements are not fulfilled within one month from the date of this communication, the sanction of power and registration will stand CANCELLED. The registration fee paid will be FOREFEITED. You are requested to contact the Asst. Ex. Engineer Ele., JIGANI Sub division, BESCOM for information and further needful.