




ಬೆಂಗಳೂರು ವಿದ್ಯುತ್ ಸರಬರಾಜು ಕಂಪನಿ ನಿಯಮಿತ  
BANGALORE ELECTRICITY SUPPLY COMPANY LIMITED

No: CEBRAZ/SEO/AEE-2/25-26/ 11 9 8 9- 90  
Email ID: [cebraz.work@gmail.com](mailto:cebraz.work@gmail.com)  
Ph No. 080-23500164  
Encl: 01 file

Office of the  
Chief Engineer Ele,  
Bangalore Rural Area Zone,  
No.1- 4, IT Park, 5th Floor, KSIIDC  
Building, Rajajinagar Industrial  
Estate, Rajajinagar, Bengaluru- 10,  
Date: -03-2026

The Executive Engineer Ele.,  
C, O & M, BESCOM,  
Hosakote division



4 / MAR 2026

Sir,

**Sub:** Arranging partial HT power supply to an extent of **500 kVA** (already sanctioned load **1200 kVA**) in favour of **M/s Crystal Solutions**, rep by authorized signatory **Sri Lakshminarayana** at sy No. 1 (Block No 38 & 39), plot No. 61-P1, Arebinnamangala village, Hi tech defence and Aerospace park KIADB (IT sector) Jala Hobli, **Vidyanagara sub-division, Hosakote division**

**Ref:** 1) T.O Power sanction No. CEBRAZ/SEO/AEE-2/2024-25/1651-55 dtd 29-05-2025  
2) T.O Administrative approval No. CEBRAZ/SEO/AEE-2/2024-25/675 dtd 23-06-2025  
3) SEE, BRC Ltr No. SEE/BRC/EE(O)/F-2(B)/2025-26/8690-92 dtd 10-02-2026

\*\*\*\*\*

With reference to the above, the superintending Engineer Ele., BRC vide ref (3) has informed the following:

- This office vide ref (1) has issued a power sanction for arranging HT power supply to an extent of **1200 kVA** in favour of **M/s Crystal Solutions**, rep by authorized signatory **Sri Lakshminarayana** at sy No. 1 (Block No 38 & 39), plot No. 61-P1, Arebinnamangala village, Hi tech defence and Aerospace park KIADB (IT sector) Jala Hobli, **Vidyanagara sub-division, Hosakote division**.
- After payment of the necessary charges as per power sanction , an administrative approval was issued by this office vide ref (2).
- Now, the SEE, BRC vide ref (3) stated that, the applicant has requested the EE, Hosakote division to service 500 kVA partially as they are not using machinery or any equipment, and AEE, Vidyanagara sub-division has inspected the spot and reported that, no installation of machinery found.

To  
AEE (2)  
11/3


Under the circumstances explained above, an approval is hereby accorded to **service the installation for 500 kVA partially from sanctioned load of 1200 kVA** duly observing prevailing BESCOM norms, subject to the following conditions:



- 1) The work shall be carried out as per the sanctioned estimate in all respects sanctioned for arranging power supply for 1200 kVA of ultimate load
- 2) For availing ultimate load of 1200 kVA in future, the approval shall be obtained from this office
- 3) The applicant shall install CTs suitable for 500 kVA in presence of MT staff under self execution

All other terms and conditions remains unaltered as mentioned in power sanction.

Yours faithfully,

  
7.3.2026  
Chief Engineer Electy,  
BRAZ, BESCOM.

Copy to:

- 1) The Superintending Engineer Ele, C, O & M, BRC for information
- 2) AEE-2/MF