

BANGALORE ELECTRICITY SUPPLY COMPANY LIMITED

(Wholly owned Government of Karnataka Undertaking)

SEE/BRC/EE(O)/AEE(O)/F 1(B)/2025 26/

5769

Office of the
Superintending Engineer (Elec),
B. (G&M), Hore Rural Circle,
BESCOM, KSSCL, 5th Floor,
"Deepa Bhavan", Bellary Road,
Hebbal, Bangalore - 560024.
Date:

21 OCT 2025

To,
M/s. Indian Oil Corporation Limited rep by Sri Shailendra
Singh Patel, [Sri Lakuma Petroleum], Sy No. 52/4, Khatha
No.239/233, Madanayakanahalli Village, Dasanapura Hobli,
Bangalore North Taluk-562162.

Sir,

Sub: Arranging power supply to an extent of 60 KW EV Charging Station under LT-6(c) [the existing premises already having a SL of 10KW bearing RR No. NP-1020 under LT-3(a) installation] in favour of M/s. Indian Oil Corporation Limited rep by Sri Shailendra Singh Patel, [Sri Lakuma Petroleum], Sy No. 52/3 & 52/4B (Old No.52/4), Khatha No.239/233, Madanayakanahalli Village, Dasanapura Hobli, Bangalore North Taluk in Madanayakanahalli Section of Nelamangala Sub-division of Nelamangala Division, "Under DCW Basis". (Application ID: 1112110250045)

- Ref: 1. As per 7th Amendment & 11th Amendment of ROE.
2. Corporate office circular No. BESCOM/CGM(OP)/AGM(OP-3)/AGM-1/21-22/Cys-134 Dated: 09.11.2021.
3. KERC/COS/DDD/1/2018-19/908, Bengaluru Dated: 22.10.2019.
4. Meeting Proceeding Ltr No. BESCOM/CGM(OP)/DGM(EV)/BC-3/2023-24/716 Dated: 12.12.2023.
5. BESCOM/BC-53/CGM(OP)/DGM(EV)/2023-24/362 Dated: 18.08.2023.
6. BESCOM/CGM(OP)/DGM(OP3)/AGM(OP)/2024-25/CYS-70 Dated: 07.10.2024.
7. EEE NEL/AEE(O)/AET/2025-26/9104-05 Dated: 18.10.2025.
8. T.O Note Approved Dated: 21.10.2025.

With reference to the above BESCOM is pleased to sanction power to execute the work of arranging power supply to an extent of 60 KW EV Charging Station under LT-6(c) [the existing premises already having a SL of 10KW bearing RR No. NP-1020 under LT-3(a) installation] in favour of M/s. Indian Oil Corporation Limited rep by Sri Shailendra Singh Patel, [Sri Lakuma Petroleum], Sy No. 52/3 & 52/4B (Old No.52/4), Khatha No.239/233, Madanayakanahalli Village, Dasanapura Hobli, Bangalore North Taluk in Madanayakanahalli Section of Nelamangala Sub-division of Nelamangala Division, "Under DCW Basis". subject to the following conditions:

- The 11 kV line of AF-6 Makali feeder feeding from 66/11KV Alur MUSS. The Station installed Capacity of 1x20 MVA + 1x31.5 MVA & the Station peak load is 13.8 MW. The Bank-1 peak load is 346 Amps & the feeder peak load of 160 Amps. The HTVR works out 5.32%.
- You have to pay the following amount at Nelamangala Sub-division, BESCOM within a period of 90 days from the date of this power sanction.
- The Total Estimate Costing of Rs. 10,94,915/- "Under DCW basis". (Application ID: 1112110250045)

SINo	Deposit details	Amount in Rs
1	2MMD for 60 KW under LT-6(c)	Rs. 54,840/- x 01
2	DCW Cost	Rs. 10,94,915/-
3	5% Tender Premium on DCW Cost	Rs. 54,746/-
4	6% GST	Rs. 4,927/-
5	9% GST	Rs. 4,927/-
6	BESCOM Establishment Cost on Total DCW Cost	Rs. 54,746/-
7	6% GST	Rs. 4,927/-
8	9% GST	Rs. 4,927/-

- The clause 8.14(b) is applicable defined in COS of KERC.
As per reference-5, the Metering arrangements for consumer availing load between 50 KW to 150 KW at low tension shall be as follows:
a. 01 No of CT & PT operated 0.2s accuracy class meter with provision for check meter.
b. 03 Nos of LT CT's of 0.2s accuracy class with burden of 2.5 VA and secondary current 1A.
c. 03 Nos of LT PT's of 0.2 accuracy class with burden of 5 VA and ratio 440/3/110/3 volts.
d. 01 No. 9f Modern
e. 02 No of test terminal Block and suitable bus bar.
You should abide by the conditions of supply of electricity of Distribution Licensees in State of Karnataka in force with subsequent amendments.
- The materials used shall confirm to ISI /BESCOM/KPTCL specifications and the materials procured should be got inspected before commencing of work by TA & QC or BESCOM authorities.
- You shall submit copies of the invoices / bills in respect of materials purchased by you for proof of having purchased the materials from the approved vendors /dealers.

