



Bangalore Electricity Supply Company Limited

(Wholly Owned By Government of Karnataka)

E-mail Id: aeehtratingtkr@gmail.com

Mob no: 9448279389



Office of the:

Asst. Executive Engineer (El)

H.T. Rating Sub-Division, Tumkur

No. AEE(El)/AE(El)/HTR/2024-25/665-68

Date:09.08.2024

To,
Asst. Executive Engineer (El),
O&M City Sub-Division-1
BESCOM, Tumkur.

Sir,

Subject: Disconnection Report of HT Installation

Ref: AEE(El)/AAO/SA(O)/2024-25/1608/01.08.2024

The H.T. Installation having the following detail has been rated for **Revenue Disconnection**
on 07.08.2024

1. Details of H.T. Installation:

Previously rated on: 16.05.2024

R.R No: THT-405	CD: 100kVA	MC: 500	Tariff: HT-2A(i)	Activity: Packing industry
-----------------	------------	---------	------------------	----------------------------

1. MULTIPLYING CONSTANT FOR BILLING:

PT Ratio X CT ratio X Dial constant

Meter PT ratio Meter CT ratio

$11KV / \sqrt{3} / 110V / \sqrt{3} \times 5/1A = 500$

2.Name & Address of the consumer:

M/s R.S Packing Industries,

Smt Veena W/o Raghavesh Sheshadri, Mallenahalli,
Arakere Post,North Section,CSD-1Tumkur

3. Observation & Advice On Technical Matter:

1. Disconnection report prepared as per the request of AEE(E), CSD-1 vide ref. (1) on 07.08.2024 to rate the installation for Revenue Disconnection.

Yours faithfully ,

Asst. Executive Engineer (El),
H.T. Rating S/D Bescom, Tumkuru

Copy for kind information to:

A. The Executive Engineer (Ele), MT division, CTZ, Chithradurga

Copy to:

B. Office copy to A.E.E. (El) H.T. Sub-Division, BESCOM, Tumkur.

C. The Accounts Officer, I/A Circle office, BESCOM, Tumkur for information.

D.The Consumer for information

1. Seals Provided Details:

SL.NO	Seals Provided to	Seals Found		Seals Left	
1	M.C. Of Meter	BMC62003	B490155 MT086110	-	-
2	T.C. of Meter	CTAZ248391		-	-
3	Optical port	PCS		-	-
4	M.D. Reset Knob	CTAZ69852		-	-
5	C.T./P.T. Chamber	CTAZ69855		-	-
6	Meter chamber Main Door	CTAZ248393		-	-
7	T.T.B.	CTAZ248392		-	-
8	Meter Reading window	PCS		-	-
9	Cable Entry Chamber	CTAZ69856		-	-

2. Details Of The Equipments:

- Cubicle type: *Cable Entry*
- Cubical Condition & Location: *GOOD*
- Supply side: *GOS*

Lightning Arrester- *Provided*
Load side isolation: *Attached LBS*

3. Details of CTs/PTs:

Sl. No.		CT Details	PT Details
1.	Make	VENKAT	VENKAT
2.	Type	INDOOR	INDOOR
3.	Class	0.2	0.2
4.	Insulation level	15/35/95kV	15/35/95kV
5.	Burden	2.5VA	25VA
6.	Ratio Connected	5/1A	11KV/ $\sqrt{3}$ /110V/ $\sqrt{3}$
7.	Sl.No., R ph	5756/19	1050/17
	Y Ph	5757/19	1051/17
	B ph	5755/19	1052/17
8.	Resin Cast	Resin Cast	Resin Cast

4. Details of Electronic Trivector Meter

Sl. No.		Meter
a.	Make	L&T
b.	Type	ER300P,NTD19.04,DLMS
c.	Class	0.2s
d.	Voltage	3X63.5V
e.	Ampere	1A
f.	Pulse/unit	50000
g.	Dial/constant	1
h.	Sl.No./Year	16101499/2016-NOV

i.	Modem Sl.No.	NSGW704980
----	--------------	------------

5. Calibration Details

	CALIBERATOR	METER
A. Voltage (V)		
B. Current (A)	No Load	No Load
C. kW/kVAr/kVA/PF		
D. Sequence	Reverse	Reverse

	Wh	VARh lg/lđ	Vah	Pf
a. MRI	Error Measurement is done using Zera			
b. Accucheck				
c. % loss	No Load			

6. METER READING	Final Readings
a. Time, Date, Month, Year	16:50 Hrs
b. Present KVA	0.0000
c. Present PF	0.000
d. Cumulative Values	
1.CkVA	4.80
2.CkWh	179.25
3.CkVARh lag	85.81
4.CkVARh lead	948.01
5.CkVAh	229.86
e. Billing values	
1. B kWh	179.25
2. B kVA	0.0021
3. B PF	1
4.MD reset count	97


 Asst. Engineer (Ele)
 H.T. Rating Sub-division
 BESCOM, Tumkur


 Asst. Executive Engineer (Ele)
 H.T. Rating Sub-Division
 BESCOM, Tumkur

-----sd-----
 Consumer/ Representative
 Signature with Seal.