



BANGALORE ELECTRICITY SUPPLY COMPANY LIMITED
(Wholly owned by Government of Karnataka)

No.EEE/AEE(O)/AE(T-2)/Klr/2025-26/
Mobile No.9448279019
Phone No.08152 222607
Email id: eeklrdivn.work@gmail.com
Encl:

636-63
280
ಕರ್ನಾಟಕ

Office of the
Executive Engineer(Ele)
C, O & M Division,
BESCOM, Kolar

Date: 24 OCT 2025

To,
Sri. B. Chalapathi
S/o Late Balakrishna
Solar City, Srinivasapura road
Kolar Tq.

Sir,

Sub: Power sanction for arranging Power Supply of 8 HP to Nursery Farm in favour of Sri. B. Chalapathi S/o Late Balakrishna at Solar City in O & M-4 Section of Kolar Urban Sub-division in Kolar Division (**Under self-execution**)- reg.

- Ref: 01. AEE Kolar urban Sub-division, Submission of file vide No. AEE/AE(T)/KUSD/2025-26/1173, Dated: 24.09.2025.
02. Estimate No. AG-266, Dated: 15.09.2025.
03. Online Application Registration ID No. 1223109250006, Sub ID No. 12231092500060001 Dated: 04.09.2025.

BESCOM is pleased to communicate the Power sanction for arranging Power Supply of 8 HP to Nursery Farm in favour of Sri. B. Chalapathi S/o Late Balakrishna at Solar City in O & M-4 Section of Kolar Urban Sub-division in Kolar Division (**Under self-execution**).


The Power Sanction is subject to the following conditions:

1. You shall construct 11 KV line, DTC and LT metering cubicle as per the BESCOM norms **under Self-Execution**.
2. The materials procured shall be in-accordance with the IE/BESCOM/KPTCL specifications and the materials shall be got inspected by QS & S / Jurisdictional Executive Engineer Ele, C, O & M Division BESCOM. The copies of the invoices / bills of the materials purchased shall be submitted as proof of purchase from the BESCOM approved vendors / dealers.
3. You have to pay the following amounts through DD Payable at SBI Kolar branch, drawn in favour of AEE, BESCOM, Kolar Urban Sub-Division within 90 days from the date of this intimation and Electrical inspectorate charges to DEI, Govt. of Karnataka.
 - a. **Rs. (5.111/-)** towards Supervision charges at 5% of estimate cost of Rs. 3,02,226/-.
 - b. **Rs. 12,160/-** towards ISD under LT-4C tariff for 8 HP load.
 - c. **Rs.5,000/-** towards Material Inspection Charges.
 - d. **Rs. 1,000/-** towards Transformer testing Charges
4. You have to execute the works as per approved estimate under self-execution through class-1 Licensed Electrical Contractor, under the supervision of BESCOM.
5. The major materials like Transformer, ACSR conductor, Metering cubicle, HT UG cable etc., shall be procured from the BESCOM approved vendors and other materials may be procured from authorized dealers /approved vendors. You have to use only Polymer

insulators as per the corporate circular no. BESCOM/BC-9/CGM(CA)/DGM(CA-3)/F-752/13-14/CYS-113 dtd 29-8-13.

6. Major materials like Transformers, RMUs, UG Cable, AB Cable, any insulated aluminium/copper conductor, Optical fiber, Insulators, GOS & CSS shall be assured guaranteed for 5 years for the defects in materials and workmanship from the date of commissioning.
7. Minimum guarantee of five years from the date of commissioning for the materials like Transformers, RMUs, UG Cable, AB Cable, any insulated aluminium/copper conductor, Optical fiber, Insulators, GOS & CSS. For the rest of equipment's/materials shall be guaranteed for the 12 months from the date of commissioning. The consumer liability shall be limited to the replacement of the any defective parts in the equipment's of his own manufacture or those of his vendors.
8. Guarantee shall be furnished for a period not less than one year for the materials used for the works. Guarantee for period not less than one year for the quality of work carried out from the date of taking over the lines and equipment's by BESCOM.
9. Approval of the Electrical Inspectorate shall be obtained for the electrical equipment and lines before Commissioning as per the KERC norms.
10. BESCOM is not responsible in whatsoever manner regarding any legal disputes that may arise at a later stage.
11. Any modification in the existing system shall be at the cost of developer with prior approval of the competent authority. Suitable safety clearance shall be maintained for the Electrical lines in accordance with the IE rules.
12. NOC from concerned authority (PGCIL/KPTCL) shall be obtained whenever EHV lines pass in the premises.
13. You should clear the outstanding arrears of the installations inside the premises, if any.
14. You should abide to the conditions of supply as per prevailing electricity act in force with subsequent amendments.
15. As per the KERC clause 4.02(g)(iv) & amendment No. KERC/CoS/D/07/10, Dtd.01.07.2010 you have to install Solar water heaters & same shall be certified & to be produced before servicing the installation.
16. An under taking letter stating that you will replace present 0.5s accuracy class LT meter and CTs with 0.2s accuracy class LT Meter and CTs at your cost.
17. An under taking letter stating that you will not engage child labor in your industry as per child labor (prohibition and regulation) act 1986.
18. The payment certificate duly signed by the Assistant Executive Engineer, Kolar Urban Sub-Division shall be sent to this office for issuing Administrative approval. Any delay in making payment, not fulfilling the above conditions within 90 days, the power sanction is deemed to be cancelled as per the conditions stipulated in the KERC.
19. You have to pay any variation / difference charges payable to BESCOM, if any in future.
20. You are requested to contact the Assistant Executive Engineer, El., C, O & M Urban Sub-division, Kolar for any clarifications.

Yours faithfully,


Executive Engineer, El.,
C, O & M Division,
BESCOM, Kolar

Copy to:-

1. The Asst. Executive Engineer (El), C, O & M Urban Sub-Division, BESCOM, Kolar.
2. AEE(O)/AE-1/OC/MF.