



Bangalore Electricity Supply Company Ltd.

HT Rating Report

9845

No. EE MT / AEE(O) / BRAZ / AEE HTR / 04HT 383

To,
The Asst. Executive Engineer (Ele.),
Dawana halli O&M Sub-Division
BESCOM, Dawana halli

Additional Load
Existing - 120 KVA
Addl - 50 KVA
Total - 170 KVA

Office of the
Executive Engineer (Ele.),
MT Division, BRAZ, BESCOM
3rd Floor, Crescent Tower
Bangalore - 560 001.

Date: 06/12/2024

Sir,

Subject : Rating Report of HT / EHT Installation

The H.T. Installation having the following details has been rated for periodical rating / complaint on 06/12/2024. You are requested to take action on the observations and advices recorded in the report. Compliance report shall be sent to this office on the observations pointed out in the report. Details are furnished in the Annexure enclosed.

1. DETAILS OF H.T. INSTALLATION :

R.R. No. 04HT 383 CD 170 KVA. Previously rated on 31-08-2024
Name & Address of the Consumer M/S SEES Granite Dawana halli
Reddanna halli in Dawana halli sub division
REVENUE.

2. OBSERVATION & ADVICE ON TECHNICAL MATTER :

Additional load sanctioned as per your letter reference no: AEE / DHT / AEE / 25-26 / 3232 dt: 05/12/2024

3. ADVICE ON REVENUE MATTER :

from 120 KVA to 170 KVA Hence the existing 7.5/11 CT is replaced by 10/11 CT & calibrated the meter before & after replacement of CT error is within permissible limits

4. DOWNLOADED TATA ANALYSIS ENCLOSED : YES / NO.

Summary of analysis if rated against complaint: meter Datasheet loaded & analysed recording found correct.

Yours faithfully,

V. K. [Signature]
Asst. Executive Engineer (Ele.),
HT Rating Sub Division, Holarate
BRAZ, BESCOM, Bangalore.

Copy for kind information to :

- The Executive Engineer Ele., MT Division, BRAZ, Bangalore.
- Executive Engineer Ele, O&M Holarate Division, BESCOM, Holarate

in case of discrepancies :

- Chief Engineer Ele., BRAZ, B'lore.
- Superintendent of Police, Vigilance
- Accounts Officer, Internal Audit.