



Bangalore Electricity Supply Company Limited

(Wholly owned by Government of Karnataka Undertaking)

No: EEE/HKTD/AEE(O)/AE(T)/2024-25/ 13986

14/3/25

Office of
Executive Engineer
C, O&M DIVISION HOSAKOTE

To

M/s Amrutha Shelters Pvt Ltd,
Sy No. 36/2,
Bidareagrahara (Chinnagenahalli) Village,
Bangalore East Taluk.

Sir/Madam,

Sub: - Arranging HT power supply to an extent of **195 KVA in HT-5 Tariff** Temporary HT installation in favour of **M/s Amrutha Shelters Pvt Ltd**, at Sy No. 36/2, Bidareagrahara (Chinnagenahalli) Village, Bangalore East Taluk in Sai Garden O&M unit of Avalahalli Sub Division Under self execution.

Ref: 1) Your Application Reg. No. **1125102250970** dated: 28.02.2025.
2) Letter No: AEE(Ele)/AVL/AE(T)/2024-25/4713 dt.07.03.2025.

BESCOM is pleased to sanction for additional power supply to an extent of **195 KVA in HT-5 Tariff** Temporary HT installation in favour of **M/s Amrutha Shelters Pvt Ltd**, at Sy No. 36/2, Bidareagrahara (Chinnagenahalli) Village, Bangalore East Taluk in Sai Garden O&M unit of Avalahalli Sub Division Under self execution subject to the following conditions:

1. Power supply will be arranged from F-9 BDA Chandragiri feeder of 66/11 KV AWHO Station.

2. You are requested to pay the following charges by DD/Cash (above 10000/- only DD will be accepted) payable at the office of the Asst. Executive Engineer (C,O&M), BESCOM Avalahalli Sub-Division within 90 Days from the date of this intimation and furnish the payment certificate for taking further action in this matter

Payment Towards	Amount(Rs.)
A.C.C	16,10,322
Fixed Charges	94,380
5% Supervision Charges	48,640
9% CGST on 5% Supervision Charges	4,378
9% SGST on 5% Supervision Charges	4,378
Total	17,62,098

Amt In Words: Seventeen lakh sixty two thousand and ninety eight only

3. To Submit payment certificate along with Self execution agreement on Rs. 200/- stamp paper regarding obtaining necessary line clearance from field staff for safe execution of works & to comply with all safety procedure duly using safety equipment's during the course of work after which a works certificate / permit will be issued to take up the works on Self execution basis.

4. The metering equipment to be installed should be conspicuously visible and at the main inference to the premises preferably with an independent entrance.

5. The power supply will be arranged at 11KV Voltage class.

6. You should own and install the necessary transformer at your end to receive and step it down to the required distribution voltage for your installation

It is proposed to provide 12.5/1A CT's with HT ETV Meter 1A class 0.2s accuracy with TOD feature 3CT's 3PTs metering cubicle.

P.T.O