



Bengaluru Electricity Supply Company Limited
(Wholly Owned Government of Karnataka Undertaking)
BESCOM GSTN No: 29AACCB1412G125

AEE/NELAMANGALA/AET

Office of the
Assistant Executive Engineer Ele.,
C,O&M, NELAMANGALA Sub Division
BESCOM, NELAMANGALA

To
M/S INDIAN OIL PETROLEUM CORPORATION LTD(LAKUMA FUE
SY NO:52/3-4 KATHA NO:23/233 MADANAYAKANAHALLI VILLAGE

Sir/Madam

Sub : Arranging power supply to an extent of 60.00 KW in favor of M/S INDIAN OIL PETROLEUM CORPORATION LTD(LAKUMA FUE SY NO:52/3-4 KATHA NO:23/233 MADANAYAKANAHALLI VILLAGE in NELAMANGALA OMU, NELAMANGALA

Ref: 1) Your application registration 1112110250045 dated 09-OCT-2025

2) AEE/NELAMANGALA /AE(T) a/ 30-OCT-2025

With reference to your application dated 09-OCT-2025 . Requesting for arranging power supply to an extent of 60.00 KW power installations in favor of M/S INDIAN OIL PETROLEUM CORPORATION LTD(LAKUMA FUE SY NO:52/3-4 KATHA NO:23/233 MADANAYAKANAHALLI VILLAGE in NELAMANGALA OMU,NELAMANGALA Sub division in hereby sanctioned subject to the following Conditions.

a.You are requested to pay the following charges by DD/cash (above 10000/- only DD will be Accepted) payable at the Office of C, O&M NELAMANGALA sub-division and furnish the payment certificate for taking further action in this matter.

Application No	Sub Application No	Tariff	Requested Load	Account Head	Amount(Rs.)
1112110250045	11121102500450001	LT6(C)-ELECTRIC VEHICLE CHARGING - LT6C	60.00 KW	62.9097-62.9097 - ESCOM Establishment Charges @ 5% on DCW(TAX)+CGST(46.9977)9%+SGST(46.9987)9%=(54746 + (54746*0.09) + (54746*0.09))	64600
1112110250045	11121102500450001	LT6(C)-ELECTRIC VEHICLE CHARGING - LT6C	60.00 KW	62.9097-62.9097 - Tender Premium @ 5% on DCW+CGST(46.9977)9%+SGST(46.9987)9%=(1094915 + (1094915*0.09) + (1094915*0.09))	1291999
1112110250045	11121102500450001	LT6(C)-ELECTRIC VEHICLE CHARGING - LT6C	60.00 KW	48.1017-48.1017 - ISD	53440
Total Amount in Rupees					1410039

. The power supply will be arranged at 400V .

The Tariff applicable to your installation will be LT6(C), or the Tariff in force From time to time.

You have to enter into an agreement with the BESCOM in the prescribed form.

Submit the Contractor's Completion-Cum-Test Report along with diagram in Duplicate.

You shall install LT metering panel approved by the BESCOM with suitable Capacity MCCB and/or ELCB.

energy meter should be placed outside the premises at the height of 5ft from the ground level.

Amount through DD should be paid in the name AEE BESCOM NELAMANGALA .

Sanction is valid up to 30 days from the date of issue.

If the above requirements are not fulfilled within one month from the date of this communication, the sanction of power and registration will be CANCELLED. The registration fee paid will be FOREFEITED. You are requested to contact the Asst. Ex. Engineer Ele., NELAMANGALA Sub Division, BESCOM for information and further needful.

Faithfully,

Your's Faithfully,



THE UNIVERSITY OF CHICAGO LIBRARY

5769

Office of the
Superintending Engineer (Elect),
TCE&M, House Journal Circle,
107th Ave., R-97C, 7th Floor,
Thermal Division, Bellary Road,
Hebbal, Bangalore - 560024.

Date:

21 OCT 2025

103
Indian Oil Corporation Limited rep by Sri Shalendra
Singh Patel, [Sri Lakshma Petroleum], Sy No. 52/4, Khatha
No 230/233, Madannayakamhalli Village, Dasanapura Hobli,
Bangalore North Taluk-562162.

三

Subj: Arranging power supply to an extent of 60 KW EV Charging Station under Li-1000 (the station is situated at 1000m location by No. RD 10/20 under LT-3(a) installation) in favour of M/s. Indian

Oil Corporation Limited rep by Sri Shalendra Singh Patel, [Sri Lakuma Petrochemicals Co Ltd], Bangalore North
52, 4th Cross No 52/49, Khobha No.239/233, Madanayakamaballi Village, Dasanapura Hobli, Bangalore North
Tatkal, in Madanayakamaballi Section of Nelamangala Sub-division of Nelamangala Division. "Under DCW
Basis". (Application ID: 1112110250045)

Basis". (Application ID: 1112110250045)

Ref : As per 7th Amendment & 11th Amendment of ROE.
Approved by : Director General
Dated: 09.11.2021.

1. Approved by the Board of Directors on 22.10.2019.
2. IERC COS D/2018-19/908, Bengaluru Dated: 22.10.2019.
3. Meeting Proceeding Ltr No. IRESCOM/CGMIOP/DGNILEV/BC-3/2023-24/716 Dated: 12.12.2023.
4. IRESCOM/BC-53/CGMIOP/DGNILEV/2023-24/362 Dated: 18.08.2023.
5. IRESCOM/CGMIOP/DGMOP3/AGMIOP/2024-25/CYS-70 Dated: 07.10.2024.
6. EEEF_NEL/AEEO/AET/2025-26/9104-05 Dated: 18.10.2025.
7. TO Note Approved Dated: 21.10.2025.

With reference to the above BESCON is pleased to sanction power to execute the work of arranging power supply to an extent of 60 KW EV Charging Station under LT-6(c) (the existing premises already having a SL of 10 KW bearing RR No. NP-1020 under LT-3(a) installation) in favour of M/s. Indian Oil Corporation Limited rep by Sri. Challenappa Singh Patel, [Sri Lakuma Petroleum], Sy No. 52/3 & 52/4B (Old No.52/4), Khatha No.239/233, Madanayakanahalli Village, Dasanapura Hobli, Bangalore North Taluk in Madanayakanahalli Section of Melamangala Sub-division of Nelamangala Division, "Under DCW Basis", subject to the following conditions:

The 11 kV line of Af-6 Makahi feeder feeding from 66/11KV Alur MUSS. The Station installed Capacity of 3x20 MVA + 1x31.5 MVA & the Station peak load is 13.8 MW. The Bank-1 peak load is 346 Amps & the Bank-2 peak load is 160 Amps. The HTVR works out 5.32%.

- | | Amount in Rs |
|--|--------------|
| 1) feeder peak load of 160 Amps. The HIVE works out to Rs. 10,94,915/- from the date of this power sanction. | |
| 2) You have to pay the following amount at Nelamangala Sub-division, BESCOM within a period of 90 days from the date of this power sanction. | |
| <u>The Total Estimate Costing of Rs. 10,94,915/- "Under DCW basis". (Application ID: 1121102500-5)</u> | |

Deposit details		Amount in Rs
SINO		
1	2MMMD for 60 KW under LT-6(c)	Rs. 54,840/- x 01
2	DCW Cost	Rs. 10,94,915/-
3	5% Tender Premium on DCW Cost	Rs. 54,746/-
4	9% GST	Rs. 4,927/-
5	9% GST	Rs. 4,927/-
6	Test & CM Establishment Cost on Total DCW Cost	Rs 54,746/-
7	9% GST	Rs. 4,927/-
8	9% GST	Rs. 4,927/-

41 The clause 8.14(b) is applicable defined in COS of KERC.

As per reference-5, the Metering arrangements for consumer availing load between 50 kW to 150 kW at

Law version shall be as follows:

- 0.1 No of CT & PT operated 0.25 accuracy class meter with provision for check meter.
- 0.3 Nos of LT CT's of 0.2s accuracy class with burden of 2.5 VA and secondary current 1A.
- 0.3 Nos of LT PT's of 0.2 accuracy class with burden of 5 VA and ratio 4+0/3/110/3 volts.
- 0.1 No. 91 Modern

e. U2 No of test terminal Block and suitable bus bar.

You should abide by the conditions of supply of electricity of Distribution licensees in State of Karnataka in force with subsequent amendments.

6) The materials used shall conform to ISI / BISCOM / IPTCL specifications and the materials procured should be got inspected before commencing of work by TA & QC or BISCOM authorities.

7) You shall submit copies of the invoices / bills in respect of materials purchased by you for proof of having purchased the materials from the approved vendors /dealers.