



**BANGALORE ELECTRICITY SUPPLY COMPANY LIMITED**  
(Wholly owned by Government of Karnataka)

No.EEE/AEE(O)/AE(T-2)/Klr/2025-26/  
Mobile No.9448279019  
Phone No.08152 222607  
Email id: eeklrdvn.work@gmail.com  
Encl:

4669-70  
380  
ಕನ್ನಡ

Office of the  
Executive Engineer(Ele)  
C, O & M Division,  
BESCOM, Kolar

Date:

125 AUG 2025

To,  
S/M Baliga & Company  
Plot No. 265 & 266  
KIADB Industrial area Narasapura  
Kolar Taluk,  
Sir,

**Intimation**

Sub: Power sanction for Arranging Additional Load to an extent of 175 KVA with existing sanctioned load of 200 KVA totaling to 375 KVA of HT Installation bearing RR No. KRRHT-120 as per request of Consumer S/M Baliga & Company at Narasapura Section in RSD Kolar, in C, O&M Division, Kolar.(Under self-execution).


- Ref: 1) Application Registration online No:61221108250002 for Dt:07.08.2025.  
2) AEE, C,O&M Rural Sub-division, Kolar letter No: AEE/AET/BESCOM/KRSD/2025-26/2205 Dated: 20.08.2025.  
3) Estimate No: KVKR-152, Dated 12.08.2025.

BESCOM is pleased to communicate power sanction to Arranging Additional Load to an extent of 175 KVA with existing sanctioned load of 200 KVA totaling to 375 KVA of HT Installation bearing RR No. KRRHT-120 as per request of Consumer S/M Baliga & Company at Narasapura Section in RSD Kolar, in C, O&M Division, Kolar.(Under self-execution).  
The Power Sanction is subject to the following conditions:

- Regular source:**  
**Line:** Existing 11kV F-7 Mahindra Feeder having peak load of 240 Amps feeding from 66/11kV Narasapura Sub-Station.  
**Sub-station:** 66/11 kV Narasapura having peak load 32.5 MWa.  
**Alternate source:** NA
- The materials procured shall be in-accordance with the IE/BESCOM/KPTCL specifications and the materials shall be got inspected by QS & S / Jurisdictional Executive Engineer Ele, C, O & M Division BESCOM. The copies of the invoices / bills of the materials purchased shall be submitted as proof of purchase from the BESCOM approved vendors / dealers.
- You have to pay the following amounts through DD, drawn in favour of AEE, BESCOM, Kolar Rural Sub-Division at SBI kolar branch within 90 days from the date of this intimation and Electrical inspectorate charges to DEI, Govt. of Karnataka.
  - Rs. 2,711/-** towards Supervision charges at 5% of estimate cost of Rs.54,214/-.
  - Rs. 3,51,750/-** towards 2MMD under HT-2a tariff for 175 KVA Add load.
  - Rs.5,000/-** towards MT Testing Charges.
- You have to execute the works as per approved estimate under self-execution through class-1 Licensed Electrical Contractor, under the supervision of BESCOM.
- The major materials like Transformer, ACSR conductor, Metering cubicle, HT UG cable etc., shall be procured from the BESCOM approved vendors and other materials may be procured from authorized dealers /approved vendors. You have to use only Polymer insulators as per the corporate circular no. BESCOM/BC-9/CGM(CA)/DGM(CA-3)/F-752/13-14/CYS-113 dtd 29-8-13.

6. Major materials like Transformers, RMUs, UG Cable, AB Cable, any insulated aluminium/copper conductor, Optical fiber, Insulators, GOS & CSS shall be assured guaranteed for 5 years for the defects in materials and workmanship from the date of commissioning.
7. Minimum guarantee of five years from the date of commissioning for the materials like Transformers, RMUs, UG Cable, AB Cable, any insulated aluminium/copper conductor, Optical fiber, Insulators, GOS & CSS. For the rest of equipment's/materials shall be guaranteed for the 12 months from the date of commissioning. The consumer liability shall be limited to the replacement of the any defective parts in the equipment's of his own manufacture or those of his vendors.
8. Guarantee shall be furnished for a period not less than five year for the materials used for the works. Guarantee for period not less than one year for the quality of work carried out from the date of taking over the lines and equipment's by BESCOM.
9. Approval of the Electrical Inspectorate shall be obtained for the electrical equipment and lines before Commissioning as per the KERC norms.
10. BESCOM is not responsible in whatsoever manner regarding any legal disputes that may arise at a later stage.
11. Any modification in the existing system shall be at the cost of developer with prior approval of the competent authority. Suitable safety clearance shall be maintained for the Electrical lines in accordance with the IE rules.
12. NOC from concerned authority (PGCIL/KPTCL) shall be obtained whenever EHV lines pass in the premises.
13. You should clear the outstanding arrears of the installations inside the premises, if any.
14. De-commission and pre-commission tests shall be done in consultation with EE, MT, BRAZ before releasing of existing CTs and after fixing of new CTs.
15. You should abide to the conditions of supply as per prevailing electricity act in force with subsequent amendments.
16. As per the KERC clause 4.02(g)(iv) & amendment No. KERC/CoS/D/07/10, Dtd.01.07.2010 you have to install Solar water heaters & same shall be certified & to be produced before servicing the installation.
17. You have to certify for not taking the child labour in your installation.
18. The payment certificate duly signed by the Assistant Executive Engineer, Kolar Rural Sub-Division shall be sent to this office for issuing Administrative approval. Any delay in making payment, not fulfilling the above conditions within 90 days, the power sanction is deemed to be cancelled as per the conditions stipulated in the KERC.
19. You have to pay any variation / difference charges payable to BESCOM, if any in future.
20. You are requested to contact the Assistant Executive Engineer, El., C, O & M Rural Sub-division, Kolar for any clarifications.

Yours faithfully,

  
**Executive Engineer, El.,**  
**C, O & M Division,**  
**BESCOM, Kolar**

**Copy to:-**

1. The Asst. Executive Engineer (Ele), C, O & M Rural Sub-Division, BESCOM, Kolar.
2. AEE(O)/AE-1/OC/MF.