

Bangalore Electricity Supply Company Ltd.

Office of the
Asst. Executive Engineer (Ele),
Mangadi, H.T. Rating Sub-Division,
BRAZ BESCOM

Date 22.12.23

Rating Engineer (Ele)
O&M Sub-Division

New [mt. 1000]

Subject : Rating Report of HT / EHT Installation

Installation having the following details has been rated for periodical rating / complaint on 22.12.23
requested to take action on the observations and advice recorded in the report. Compliance report shall be sent
on the observations pointed out in the report. Details are furnished in the Annexure enclosed.

ALSO OF H.T. INSTALLATION : 100+100 Previously rated on 26.06.22 mf
 No. PNH1ME006 CD 200 KVA CTR. 511 to 1011 A Meter Constant 500 to 1000
 Activity Govt Hospital (HS 210)

Name & Address of the Consumer Medical Officer
 ಮುಖ್ಯ ವೈದ್ಯಾಧಿಕಾರಿ ಕಛೇರಿ Community Health Center
 ಹರಿಹರನ ಬಳಿ, Mangadi

OBSERVATION & ADVISE ON TECHNICAL MATTER:

The installation meter is calibrated before & after CT.
 replacement work on account of additional load, the meter records
 is found to be within permissible limits.

ADVICE ON REVENUE MATTER:

New [mt. 1000]

4. DOWNLOADED DATA ANALYSIS ENCLOSED: YES/NO.


Summary of analysis if rated against complaint

Copy for kind information to:

1. The Executive Engineer Ele., MT Division, BRAZ, Bengaluru.
2. Executive Engineer Ele., O & M Division, BESCOM,

In case of discrepancies:

3. Chief Engineer Ele., BRAZ, Bengaluru.
4. Superintendent of Police, Vigilance
5. Accounts Officer, Internal Audit.



Yours faithfully,
 Asst. Executive Engineer (Ele)
 H.T. Rating Sub-Dvn, BRAZ
 (ಹರಿಹರನ ಬಳಿ, ಎ.ಎಸ್)
 ಮುಖ್ಯ ವೈದ್ಯಾಧಿಕಾರಿ ಕಛೇರಿ (ಎ)
 ಹರಿಹರನ ಬಳಿ, (ಹರಿಹರನ ಬಳಿ) ಬಳಿ ಕಛೇರಿ
 ಹರಿಹರನ ಬಳಿ, ಹರಿಹರನ ಬಳಿ, ಹರಿಹರನ ಬಳಿ