



Bengaluru Electricity Supply Company Limited
(Wholly Owned Government of Karnataka Undertaking)
BESCOM GSTN No: 29AACCB1412G1Z5

AEE/JIGANI/ (AET)

Office of the
Assistant Executive Engineer Ele.,
C,O&M, JIGANI Sub Division
BESCOM , JIGANI

To
SENIOR MANAGER
SY NO.254/1 PROP NO.522/43 TO 48 MADAPATTANA VILLAGE

Sir/Madam

Sub : Arranging power supply to an extent of **49.00 KW** in favor of SENIOR MANAGER SY NO.254/1 PROP NO.522/43 TO 48 MADAPATTANA VILLAGE in JIGANI OMU, JIGANI

Ref : 1) Your application registration **1324105250007** dated **05-MAY-2025**

2) AEE/JIGANI /AE(T) a/ **04-JUL-2025**

With reference to your application dated **05-MAY-2025** . Requesting for arranging power supply to an extent of **49.00 KW** power installations in favor of SENIOR MANAGER SY NO.254/1 PROP NO.522/43 TO 48 MADAPATTANA VILLAGE in JIGANI OMU, JIGANI Sub division in hereby sanctioned subject to the following Conditions.

a. You are requested to pay the following charges by DD/cash (above 10000/- only DD will be Accepted) payable at the Office of C, O&M JIGANI sub-division and furnish the payment certificate for taking further action in this matter.

Application No	Sub Application No	Tariff	Requested Load	Account Head	Amount(Rs.)
1324105250007	13241052500070001	LT6(C)- ELECTRIC VEHICLE CHARGING - LT6C	49.00 KW	61.9047-(WITH TAX) 5% Supervisory Charge(61.904)+CGST(46.9977)9%+SGST(46.9987)9%= (23018 + (23018*0.09) + (23018*0.09))	27162
1324105250007	13241052500070001	LT6(C)- ELECTRIC VEHICLE CHARGING - LT6C	49.00 KW	61.9067-61.9067-TRANSFORMER TESTING FEE	1000
1324105250007	13241052500070001	LT6(C)- ELECTRIC VEHICLE CHARGING - LT6C	49.00 KW	48.1017-48.1017 - ISD	45080
Total Amount in Rupees					73242

- b. The power supply will be arranged at 400V .
- c. The Tariff applicable to your installation will be LT6(C), or the Tariff in force From time to time.
- d. You have to enter into an agreement with the BESCOM in the prescribed form.
- e. Submit the Contractor's Completion-Cum-Test Report along with diagram in Duplicate.
- f. You shall install LT metering panel approved by the BESCOM with suitable Capacity MCCB and/or ELCB.
- g. Energy meter should be placed outside the premises at the height of 5ft from the ground level.
- h. Amount through DD should be paid in the name AEE BESCOM JIGANI .
- i. Intimation is valid up to 30 days from the date of issue.

In case the above requirements are not fulfilled within one month from the date of this communication, the sanction of power and registration will stand CANCELLED. The registration fee paid will be FOREFEITED. You are requested to contact the Asst. Ex. Engineer Ele., JIGANI Sub division, BESCOM for information and further needful.

Your's Faithfully,

**Assistant Engineer (Technical),
JIGANI, BESCOM**

Your's Faithfully,

**Assistant Executive Engineer Ele.,
JIGANI, BESCOM**

Copy to:

- 1.The Executive Engineer Ele. C, O&M CHANDAPURA Division, BESCOM.
- 2.The Asst. Executive Engineer Ele., C,O&M JIGANI Sub division, BESCOM.