

Bangalore Electricity Supply Company Ltd.

HT Rating Report

9615 Office of the
Executive Engineer (Ele.),
MT Division, BRAZ, BESC
3rd Floor, Crescent Tower
Bangalore - 560 001.

Asst. Executive Engineer (Ele.),
Devaras Halli O&M Sub-Division
BESC, Devaras Halli

Additional Load
Existing - 275 kVA
Additional - 55 kVA
Total 330 kVA

Date: 14/12/2025

Subject : Rating Report of HT / EHT Installation

H.T. Installation having the following details has been rated for periodical rating / complaint on 14/12/2025
are requested to take action on the observations and advices recorded in the report. Compliance report shall be sent
to this office on the observations pointed out in the report. Details are furnished in the Annexure enclosed.

DETAILS OF H.T. INSTALLATION :

Previously rated on 23-04-2025
R.R. No. DYHT 12 CD 330 KVA. Meter Constant 2000 Activity
Name & Address of the Consumer. M/L JTC FILTERONA LIMITED: Industry
Tobbaro Yerithigana Halli village in Devaras
Halli sub division BESC.

OBSERVATION & ADVICE ON TECHNICAL MATTER :

AS Per your letter reference no. AEE / DHL / AEE /
25-26/3860 of 15/12/2025 Additional load sanctioned
ADVICE ON REVENUE MATTER from 275 kVA to 330 kVA. Hence ~~the~~
the existing 15/1A C.T. replaced by 20/1A
C.T. meter calibrated before & after replacement
of C.T. error is within permissible limit.

DOWNLOADED TATA ANALYSIS ENCLOSED : YES / NO.

Summary of analysis if rated against complaint. No per date down loaded &
analyzed recording found correct.

R for k-1500- }
R for k-2000- } il- 2628.591

Yours faithfully,

V. M. Kote
Asst. Executive Engineer (Ele.),
HT Rating Sub Division, Hosalkote
BRAZ, BESC, Bangalore.

For kind information to :

The Executive Engineer Ele., MT Division, BRAZ, Bangalore.

Executive Engineer Ele, O&M Hosalkote Division, BESC, Hosalkote

For kind information to :

Chief Engineer Ele., BRAZ, B'lore.

Superintendent of Police, Vigilance

Accounts Officer, Internal Audit.