



# Bangalore Electricity Supply Company Limited

(Wholly Owned By Government of Karnataka)

E-mail Id: aecmttumkur2@gmail.com  
Mob no: 9980271595

Office of the:  
Asst. Executive Engineer (El)  
L.T. Rating Sub-Division-2, Tumkur

No. AEE(E)/MT-2/2025-26/ 995-96

Date: 06/11/2025

To,  
Asst. Executive Engineer (El),  
O&M Rural Sub-Division-2  
BESCOM, Tumkur.

Sir,

Subject: Pre-Commission test report of LT installation  
Ref: ಸಕಾನಿಷಂ(ಎ)/ಸಇಂ(ತಾ)/ಗ್ರಾಉಪ-2/2025-26/3090 ದಿನಾಂಕ: 04/11/2025

The Pre-Commission test is conducted on 04.11.2025 & 05.11.2025 for L.T. installation with the following details.

## DETAILS OF L.T. INSTALLATION:

|                 |                     |                    |
|-----------------|---------------------|--------------------|
| R.R No: PC Test | Sanction Load: 67KW | MC: 500            |
| Tariff: LT-3    |                     | Activity: Building |

1. Multiplying Constant For Billing :  $\frac{\text{PT Ratio} \times \text{CT ratio} \times \text{Dial constant}}{\text{Meter PT ratio} \times \text{Meter CT ratio}}$

$$440\text{v}/\sqrt{3} / 110\text{V}/\sqrt{3} \times 125/1\text{A} = 500$$

2. Name & Address of the consumer : Sri G Narasimha Murthy  
Bin Late V R Gangappa  
A K Kaval Tumkur.

| CTs Sl. No | CT PRI | CT SEC | PTs Sl.NO | PT PRI | PT SEC |
|------------|--------|--------|-----------|--------|--------|
| 25465/25   | 125 A  | 1A     | 324339/25 | 440V   | 110 V  |
| 25466/25   | 125 A  | 1A     | 324341/25 | 440V   | 110 V  |
| 25467/25   | 125 A  | 1A     | 324342/25 | 440V   | 110 V  |

Yours faithfully

Asst. Executive Engineer (El)  
L.T. Rating-MT S/D-2 Bescom,  
Tumkur

## Copy for kind information to:

A. The Executive Engineer (Ele), MT division, CTZ, Chithradurga

## Copy to:

- B. The Accounts Officer, I/A Circle office, BESCOM, Tumkur for information.
- C. The Consumer for information
- D. Office copy



# BANGALORE ELECTRICITY SUPPLY COMPANY LIMITED

(WHOLLY OWNED GOVT. OF KARNATAKA UNDERTAKING)

OFFICE OF THE EXECUTIVE ENGINEER(Ele), C, O&M Division, BESCOM, TUMKUR-572101

Ph:0816-2955552



E-mail: eetumkurdvn@gmail.com

Date: 15 OCT 2025

WEC No : E-902/13.10.2025

SELF EXECUTION WORK MATERIALS NOT TO DRAW

## WORK EXECUTION CERTIFICATE

Subj: For Arranging power supply to an extent of 85KWs (67KW+18KW) Commercial Installations under Regln. 9.0 in favour of Sri.G.Narasimhamurthy S/o Late. V.R. Gangappa at Honnudiike Hand post, AK Kaval, Tumkur in Gulur Section, RSD-2 Tumkur. (Under Self-Execution)

- Ref:-
1. BESCOM/CGM(ProJ)/DGM-3/BC-14/CYS-117/13.01.2023.
  2. CGM(OP)/DGM(OP-1)/AGM(OP-3)/AE-1/BC-05/2020-21/CYS-164/29.03.2021.
  3. CEA Measures relating to Safety & Electrical Supply Regulations-2010.
  4. Hon. Supreme Court Order : Civil Appeal No.14604/2024 & 4605/2024 Dated : 17.12.2024.
  5. CGM(OP)/DGM-3/BC-05/F-341/2025-26CYS-02 / Dated : 04.04.2025.
  6. Circle Office Intimation Letter No: SE(Ele)/Tkr/EE(O)/AEE/T-1/2025-26/5186-88/23.09.2025.
  7. Payment Certificate No: AEE(Ele)/RSD-2/TA/2025-26/2607/24.09.2025.
  8. Circle Office Letter No: SE(E)/Tkr/BE(O)/AEE/T-1/2025-26/5941-42/06.10.2025.
- \*\*\*\*\*

\*Approval is accorded by letter cited under ref.(6&8) For Arranging power supply to an extent of 85KWs (67KW+18KW) Commercial Installations under Regln. 9.0 in favour of Sri.G.Narasimhamurthy S/o Late. V.R. Gangappa at Honnudiike Hand post, AK Kaval, Tumkur in Gulur Section, RSD-2 Tumkur. (Under Self-Execution)

| Sl No | Particulars                         | Amount                               | Receipt No              | Date       |
|-------|-------------------------------------|--------------------------------------|-------------------------|------------|
| 1     | Deposit Charges                     | 1,07,180+28,800+2,910<br>=1,38,890/- | 2223201005368/5372/5374 |            |
| 2     | SC Charges at 05% E.C.              | 48,802/-                             | 2223201005373           |            |
| 3     | SC charges                          | 250/-                                | 2223201005369           | 24.09.2025 |
| 4     | Transformer Testing charges         | 1,000/-                              | 2223201005370           |            |
| 5     | LT Metering Cubicle Testing charges | 4080/-                               | 2223201005371           |            |

The materials purchased by the consumer shall be inspected by Q.S & S wing, BESCOM, as per circular No: BESCOM/GM(QS&S)/DGM-3/BC-11/F-1425/2013-14/CYS-125/19.02.2014.

**The Transformer Shall be Tested at Transformer testing centre in Tumkur as per the corporate office circular vide under Ref-(2) and before execution this certificate shall be given to the concerned A.E.(E) of the Sub- Division. The above work should be carried out under supervision of concerned O&M Staff.**

The Applicant should submit the LEC Name, Address, Copy of License and other Documents to concerned Sub division Asst. Executive Engineer(Ele) and Section Officer before issuing of Line Clear to carryout the said work. You should return the released materials to Tumkur divisional store after the work order issued.

Take Necessary safety precautions while executing the work by Class-1 electrical contractor. If any Electrical / Mechanical accidents occurred without any safety precautions by the Electrical Contractor The BESCOM is not responsible.

**The Supervision and monitoring of UG Cable to be added to the existing network should be Supervise by PMU Section, Corporate Office, BESCOM vide Ref-(1).**

You should return the released materials to Tumkur divisional store after the work order issued. Sub division Officer & Section Officer before commencement of the work.

The payment made doesnot confir any rights on applicant to avail the power sanction which is subject to the fulfillment of prevailing BESCOM/KEKC norms.

P.T.O

**Registered Office:** Corporate Office, KR Circle, BESCOM, Bangalore-560001

website : bescom.karnataka.gov.in

ANNEXURE-1

## 1. Details of Seals provided

| SL. No | Seals Provided to       | Billing Meter           |            |
|--------|-------------------------|-------------------------|------------|
|        |                         | Seals Found             | Seals Left |
| 1      | B.C. Of Meter           | BRM0581840/<br>MT112247 | Retained   |
| 2      | T.C. of Meter           | -                       | CTAZ168196 |
| 3      | Optical port            | -                       | Unnumbered |
| 4      | M.D. Reset Knob         | -                       | CTAZ168195 |
| 5      | Test Terminal Box.      | -                       | CTAZ168197 |
| 5      | Meter chamber Main Door | -                       | CTAZ168198 |
| 6      | C.T./P.T. Chamber       | -                       | CTAZ168199 |

## 2. DETAILS OF THE EQUIPMENTS:

- a. Cubicle type: *Cable Entry*  
b. Cubical Condition & Location: *GOOD*

## 3. Details of CTs/PTs:

| SL No. |                 | Billing Meter |                                     |
|--------|-----------------|---------------|-------------------------------------|
|        |                 | CT Details    | PT Details                          |
| 1.     | Make            | Kalpa         | Kalpa                               |
| 2.     | Type            | In Door       | In Door                             |
| 3.     | Class           | 0.2 S         | 0.2                                 |
| 4.     | Burden          | 2.5 VA        | 5 VA                                |
| 5.     | Ratio Connected | 125/1A        | 440v/ $\sqrt{3}$ / 110V/ $\sqrt{3}$ |
| 6.     | SL No. 'R' Ph   | 25465/25      | 324339/25                           |
|        | Y Ph            | 25466/25      | 324341/25                           |
|        | B'ph            | 25467/25      | 324342/25                           |

## 4. Details of Electronic Trivector Meter

|    |               | Billing Meter         |
|----|---------------|-----------------------|
| a. | Make          | L & T                 |
| b. | Type          | ER300P, WR300BB11K4RS |
| c. | Class         | 0.2 S                 |
| d. | Voltage       | 3X63.5V               |
| e. | Ampere        | 1A                    |
| f. | Pulse/unit    | 50,000                |
| g. | Dial/constant | 1                     |
| h. | SL No/Year    | 25004523 / May-2025   |



# Bangalore Electricity Supply Company Limited

(Wholly owned Government of Karnataka Undertaking)

## New Connection Application Acknowledgement

Application Id: 2223209250012

Sub Division: TUMKUR RURAL SUB DIVISION2

### Application Details

|                  |                                                                    |                     |                                                                    |
|------------------|--------------------------------------------------------------------|---------------------|--------------------------------------------------------------------|
| Applicant Name   | G NARASIMHAMURTHY AND L R GEETHA                                   | Father/Husband Name |                                                                    |
| Perm Address     | S/O LATE V R GANGAPPA A K KAVAL<br>KH NO 1876/01, 1877/02, 1877/03 | Corresp Address     | S/O LATE V R GANGAPPA A K KAVAL<br>KH NO 1876/01, 1877/02, 1877/03 |
| Mobile           | 9448373611                                                         | Email Id            | gnarasimhamurthy@gmail.com                                         |
| Application Date | 12-SEP-2025                                                        |                     |                                                                    |

### Location Details

|         |           |         |           |
|---------|-----------|---------|-----------|
| Taluk   | TUMKUR    | GP      | HOLAKALLU |
| Village | A.K.KAVAL | Pincode | 0         |

### Additional Details

|                     |                                    |                       |   |
|---------------------|------------------------------------|-----------------------|---|
| Premises Located in | Village Panchayat / Gram Panchayat | Site Dimension (Sq m) | 0 |
|---------------------|------------------------------------|-----------------------|---|

### Document Details

| Proof Type                  | Document Type                                        | Proof ID NO  |
|-----------------------------|------------------------------------------------------|--------------|
| COMP_CERTIFICATE            | Completion-Cum test report along with wiring diagram | 2            |
| IDENTITY_PROOF              | Aadhar Card                                          | 309791697704 |
| PROOF_OWNERSHIP_NAME_CHANGE | General Licence issued by the competent Authority    | 1            |

### Registration Fees Details

| Application ID | Sub Application No | Types of Charges          | Amount in Rs. | CGST(9%) | SGST(9%) | Total Amount |
|----------------|--------------------|---------------------------|---------------|----------|----------|--------------|
| 2223209250012  | 22232092500120001  | Registration Fees-61.9067 | 250           | 0        | 0        | 250          |
| 2223209250012  | 22232092500120002  | FEES                      | 0             | 0        | 0        | 0            |
| Total :        |                    |                           | 250           | 0        | 0        | 250          |

Total Amount Payable: Rs. 250

### L T New Connection Details (Multiple)

| Application ID | Sub Application NO | Power Supply Required For | Nature of Business        | Requested Load KW/HP | Tariff     | Phase   | Billing Type | Source Type |
|----------------|--------------------|---------------------------|---------------------------|----------------------|------------|---------|--------------|-------------|
| 2223209250012  | 22232092500120001  | Multi Storage Buildings   | Kalyan Mantaps / Choultry | 67.0 KW/0.0 HP       | LT3A-Rural | 3-PHASE | POST PAID    | SMART METER |
| 2223209250012  | 22232092500120002  | Multi Storage Buildings   | Kalyan Mantaps / Choultry | 18.0 KW/0.0 HP       | LT3A-Rural | 3-PHASE | POST PAID    | SMART METER |

NOTE: Registration Fees is to be Paid within 30 days of Application Registration

855W

