

## <u>ಬೆಂಗಳೂರು ವಿದ್ಯುತ್ ಸರಬರಾಜು ಕಂಪನಿ ನಿಯಮಿತ</u>

(ಸಂಪೂರ್ಣ ಕರ್ನಾಟಕ ರಾಜ್ಯ ಸರ್ಕಾರದ ಸ್ವಾಮ್ಯಕ್ಕೆ ಒಳಪಟ್ಟಿದೆ)

ಸಂಖ್ಯೇ ಅಇಂ(ವಿ)/ರಾವ್ಯ/ಕಾಇಂ(ಕ)/ಸಕಾಇ/2025-26/

ಲಗತ್ತು:

5457-59

Email:sermgc.work@gmail.com

Phone No. 080-28488780

BESCOM GST NO: 29AACCB1412G1Z5

ರವರ ಕಬೇರಿ. ಅಧೀಕಕ ಇಂಜನಿಯರ್(ವಿ), ವಾಣಿಜ್ಞ, ಕಾರ್ಯ & ಪಾಲನಾ ರಾಮನಗರ ವೃಶ್ರ ಬಿವಿಕಂ, ಟಟಎಂಸಿ ಕಟ್ಟಡ, ಕೆಂಗ್ಸರಿ, ಬೆಂಗಳೂರು-560060.

1 4 OCT 2025

To

Smt. Lakshmi Reddy W/o Vijay Babu, Sy No. 94, KH No. 139/139, Sakalavara Village, Jigani Hobli, Anekal Taluk, Bangalore Urban District,

ಅಧಿಕ ವಿದ್ಯುತ್ ಭಾರ

ಎಸಾನ್ಯರೆ,

ವಿಷಯ: ನಿಮ್ಮ ಹಾಲಿ ಬಹುಮಹಡಿ ಕಟ್ಟಡಕ್ಕೆ ಅಧಿಕ 52 ಕಿ.ವ್ಯಾ (ಹಾಲಿ 30 ಕಿ.ವ್ಯಾ+ ಅಧಿಕ 52 ಕಿ.ವ್ಯಾ:

ಒಟ್ಟು 82 ಕಿ.ವ್ಯಾ) ಅಧಿಕ ವಿದ್ಯುತ್ ಭಾರ (ವಾಣಿಜ್ಯ) ಉದ್ದೇಶಕ್ಕೆ ವಿದ್ಯುತ್ ಸಂಪರ್ಕ ಕಲ್ಪಿಸುವ ಬಗ್ಗೆ.

ಉಲ್ಲೇಖ: ಕಾನಿಇಂ(ವಿ)/ಚಂದಾ /ಸಕಾನಿಇಂ(ಕ)/ಸಇಂ(ತಾಂ)/2025-26/7061-62 ದಿ: 08.10.2025 ಚಂದಾಮರ

ವಿಬಾಗ.

Application ID: 61324108250017

ನಿಮ್ಮ ಮನವಿಯಲ್ಲಿ ನೀವು ಕೋರಿರುವಂತೆ ಅಧಿಕ 52 ಕಿ.ವ್ಯಾ (ಹಾಲಿ 30 ಕಿ.ವ್ಯಾ + ಅಧಿಕ 52 ಕಿ.ವ್ಯಾ; ಒಟ್ಟು 82 ಕಿ.ವ್ಯಾ) ವಿದ್ಯುತ್ ಭಾರವನ್ನು ಕೆ.ಇ.ಆರ್.ಸಿ ನಿಯಮ 3.1.5ರ ಪ್ರಕಾರ ಈ ಕೆಳಗೆ ಸೂಚಿಸಿರುವ ಷರತ್ತುಗಳ ಮೇರೆಗೆ ಮಂಜೂರು ಮಾಡಲಾಗಿದೆ ಹಾಗೂ ಮಂಜೂರಾತಿಯು ಈ ದಿನಾಂಕದಿಂದ 90 ದಿವಸಗಳವರೆಗೆ ಚಾಲ್ತಿಯಲ್ಲಿರುತ್ತದೆ. (ಹಾಲಿ 30 ಕಿ.ವ್ಯಾ + ಅಧಿಕ 52 ಕಿ.ವ್ಯಾ; ಒಟ್ಟು 82 ಕಿ.ವ್ಯಾ).

- l. ತಾವು ಹಾಲಿ ಕಟ್ಟರುವ ಕಟ್ಟಡದ ವಿಸ್ತೀರ್ಣ 4000 ಚ.ಮೀ, Ground Floor ಇರುತ್ತದೆ. ಹೊಸದಾಗಿ ನೀವು ಕೋರಿರುವ ಲಧಿಕ ವಿದ್ಯುತ್ ಪ್ರಮಾಣ 52 ಕಿ.ವ್ಯಾ (ವಾಣಿಜ್ಯ)
- 2. ಸದರಿ ಸ್ಥಾವರಕ್ಕೆ ಹಾಲಿ ಇರುವ F-16 C K Pallya Feeder, 66/11KV Gollahalli MUSS ಉಪಸ್ಥಾವರದಿಂದ ವಿದ್ಯುತ್ ಸರಬರಾಜು ಮಾಡಲಾಗುವುದು.
- ಚಾಲ್ತಿಯಲ್ಲಿರುವ ಎಲ್.ಟಿ.–3 ಜಕಾತಿಯು ನಿಮ್ಮ ಸ್ಥಾವರಕ್ಕೆ ಅನ್ವಯಿಸಲ್ಪಡುತ್ತದೆ.
- 4. ತಮಗೆ ಸರಬರಾಜು ನೀಡಲು ತಗಲುವ ಸ್ವಯಂ ಕಾಮಗಾರಿ ಅಂದಾಜು ಪಟ್ಟಿಯ ವೆಚ್ಚ ರೂ. 7,13,798/–ಆಗಿರುತ್ತದೆ.
- 5. ಈ ಕೆಳಕಂಡ ರೇವಣಿ/ಶುಲ್ಡಗಳನ್ನು ಸ.ಕಾ.ನಿ.ಇಂ(ವಿ), ಜಿಗಣಿ ಉಪ–ವಿಭಾಗದಲ್ಲಿ DD ಮೂಲಕ ಪಾವತಿಸುವುದು

Page 1 of 5

Applicant Name: Smt. Lakshmi Reddy W/o Vijay Babu Reddy,

2MMD:		9 % CGST (in Rs.)	9% SGST (in Rs.)	Total Amount in Rs.
		(111 143.)	(iii ka.)	1,3,
52KW * 01 Nos: Tariff LT-3 (85280) on Existing RR No. SKP- 36(EX load 30KW +Add Load 52KW = Total Load 82KW)	85,280/-	0 0		85.280/-
% Supervision Charges on otal Estimate Cost Rs. 13,798/-)	35,265/-	3,174/-	3,174/-	41,613/-
ansformer Testing fee	1,000/-	О	0	1,000/-
MC Testing fee	4,080/-	0	0	4,080/-
	one thousand and	nine hun	dred	1,31,973
	36(EX load 30KW +Add Load 52KW = Total Load 82KW) 6 Supervision Charges on otal Estimate Cost Rs. 13,798/-) ansformer Testing fee MC Testing fee	36(EX load 30KW +Add Load 52KW = Total Load 82KW) % Supervision Charges on otal Estimate Cost Rs. 13.798/-) ansformer Testing fee 1,000/- MC Testing fee 4,080/- ount (Rupees One Lakh thirty one thousand and	36(EX load 30KW +Add Load 52KW = Total Load 82KW) % Supervision Charges on otal Estimate Cost Rs. 13.798/-) ansformer Testing fee  MC Testing fee  4,080/- 0 ount (Rupees One Lakh thirty one thousand and nine hun	36(EX load 30KW +Add Load 52KW = Total Load 82KW) % Supervision Charges on otal Estimate Cost Rs. 13.798/-) ansformer Testing fee 1,000/- 0 0 MC Testing fee 4,080/- 0 0 ount (Rupees One Lakh thirty one thousand and nine hundred

- As per BESCOM Circular No: BESCOM/ GM (QS&s) / DGM-3 /AGM- I /BC-11 / 2024 -25 /Cys-141, dt:05.12. 2024.Dry type transformers required to create infrastructure shall be purchased from BESCOM approved Vendors only.
- If Dry type LBS/500KVA/CSS/transformer has been installed under self-execution, an under taking shall be furnished that the same shall be maintained for life time by the applicant.
- 7. As per BESCOM order No: BESCOM/CGM(OP)/DGM (OP--1)/FY 2021-2022/CYS-19 Dt:17.05.2021. The sub divisional officers ensure the transformer quality and rating at the authorized test bench/ Divisional stores duly collecting transformer test certificate issued by the concerned MT division before servicing of installation.
- As per BESCOM Circular No: BESCOM/ GM (QS&s) / DGM-3 /AGM- I /BC-11 / 2024 -25 /Cys-15. dt:19.04.2024. All dry type transformers procured under Self-execution shall be got tested at the nearest test bench center and duly collecting transformer test certificate issued by the concerned MT division.
- 9. As per BESCOM Circular vide ref:-BESCOM/CGM(OP)/DGM(OP3)/2024-25/Cys-95 Dates:-15.02.2025 & CYS-102 dated 25-03-2025. The power supply shall be arranged to the above said installations through "Smart Energy Meter in line with its capacity and quantum of load requirement in BESCOM juridiction".
- 10. Guanatee shall be furnished for a period of not less than one year for the materials used in the works as well as for the quality of the work carried out from date taking over of the lines and equipments by BESCOM.
- 11. Provide 1 ETV Meter with suitable CTs.

Page 2 of 5

Applicant Name: Smt. Lakshmi Reddy W/o Vijay Babu Reddy,

- 12. ಸಿಂಗಲ್ ಫೇಸ್ 0 ಸಂಖ್ಯೆ 5–30 ಅಂಪ್ಡ್ ೩ ಮೂರು ಫೇಸ್ 0 ಸಂಖ್ಯೆ 3-5–30 ಅಂಪ್ಡ್ ಓಟಿ ಗಳನ್ನು ತಾವ್ರ ಸಿಸುಮಾನುಗಾರ ತಮ್ಮ ವೆಚ್ಚದಲ್ಲಿ ಆಗವಡಿಸಿಕೊಳ್ಳತ್ವದ್ದು
- ನಿಗಮದಿಂದ ಅನುಮೋದಿಸಲ್ಪಟ್ಟ Vendors ಗಳಿಂದ 5 ಸ್ಟಾರ್ ಹೊಂದಿರುವ ಸ್ಕೂಕ್ತ ಸಾಮರ್ಥ್ಯದ ಪರಿವರ್ತಕವನ್ನು ಸ್ಥಯಂ-ಕಾರ್ಮಾರಿ ಮೋಜನೆಯಡಿಯಲ್ಲಿ ಅನುಮೋದಿಸಿದ ಅಂದಾಜುಪಟ್ಟಿಯ ಪ್ರಕಾರ ಅಳವಡಿಸುವುದು.
- 14. Before commencement of work, all material shall be inspected from the BESCOM authorities.
- 15. ನಿಮ್ಮ ಕಟ್ಟಡಕ್ಕೆ ವಿದ್ಯುತ್ ಸಂಪರ್ಕ ಅಳವಡಿಸುವ ಮುನ್ನ ನಿಯಮಾನುಸಾರ ಸೋಲಾರ್ ವಾಟರ್ ಹೀಟರ್ ಗಳನ್ನು ಕಡ್ಡಾಯವಾಗಿ ಅಳವಡಿಸುವುದು.
- 16. ವಿಮೃತ್ ಸಂಪರ್ಕಕ್ಕಾಗಿ ನೀವು ಸಲ್ಲಿಸಿರುವ ಬಿ.ಬಿ.ಎಂ.ಪಿ./ಬಿ.ಎಂ.ಆರ್.ಡಿ.ಎ./ನಗರ ಪಾಲಿಕೆ/ಗ್ರಾಮ ಪಂಚಾಯಿತಿಯಿಂದ ಅನುಮೋದನೆಗೊಂಡ ನಕ್ಷೆ/ಮಾಲೀಕತ್ವದ ದಾಖಲೆಗಳು ಹಾಗು ಇತರೆ ದಾಖಲಾತಿಗಳು ನಕಲಿ/ಸುಳ್ಳು ಎಂದು ಕಂಡು ಬಂದಲ್ಲಿ ಯಾವುದೇ ಮುನ್ನೂಚನೆ ನೀಡದೆ ನಿಮ್ಮ ಕಟ್ಟಡಕ್ಕೆ ಏರ್ಪಡಿಸಿದ್ದ ವಿದ್ಯುತ್ ಸಂಪರ್ಕವನ್ನು ಕಡಿತಗೊಳಿಸಲಾಗುವುದು ಮತ್ತು ನೀವು ಬಿ.ವಿ.ಕಂ.ಗೆ ಪಾಪತಿಸಿರುವ ಶೇವಣಿಗಳನ್ನು ಮುಟ್ಟುಗೋಲು ಹಾಕಿಕೊಳ್ಳಲಾಗುವುದು.
- 17. ನಿಮ್ಮ ಕಟ್ಟಡದ ಎತ್ತರ 15 ಮೀ ಮತ್ತು ಅದಕ್ಕಿಂತ ಜಾಸ್ತಿ ಇದ್ದರೆ ನಿಯಾಮಾನುಸಾರ ವಿದ್ಯುತ್ ಪರಿವೀಕ್ಷಕರ ಅನುಮತಿಯನ್ನು ಪಡೆಯಬೇಕು.
- 18. (a) An electrical room with RCC roof having clear floor area of 5 metres X 4 metres with a vertical clearance of 2.75 meters with locking facility, exhaust fans and adequate size of cable duct, shall be provided at the ground floor within the Applicant's premises nearer to the main entrance for installing floor mounted distribution transformer and associated switchgear or
  - (b) A clear space of 3 metres X 5 metres open to the sky shall be provided within the Applicant's premises preferably at the main entrance for installing structure mounted distribution transformer and switchgear.
- 19. ನಿಗಮದಿಂದ ಅನುಮೋದಿಸಲ್ಪಟ್ಟ ಸೂಕ್ತ ಸಾಮರ್ಥ್ಯದ ಸರ್ಕ್ಯೂಟ್ ಬ್ರೇಕರ್ ಮತ್ತು ಇ.ಎಲ್.ಸಿ.ಬಿ.ಯನ್ನು ಮಾಪಕ ಪೆಟ್ಟಿಗೆಯಿಂದ ಒಂದು ಮೀಟರ್ ಒಳಗೆ ಮತ್ತು ಭೂಮಿಯಿಂದ 0.6 – 1.6 ಮೀ ಎತ್ತರದ ಒಳಗೆ ನೆಲ ಮಾಳಿಗೆಯಲ್ಲಿ ಅಳವಡಿಸುವುದು.
- 20. ನಿಮ್ಮ ಆವರಣದಲ್ಲಿ ಹಾಲಿ ಇರುವ 1\*63ಕೆ.ವಿ. ಎ (DTC) ಪರಿವರ್ತಕದಿಂದ 1\*100 ಕೆ.ವಿ. ಎ (Cable Entry Type ) ಪರಿವರ್ತಕಕ್ಕೆ ಮೇಲ್ದರ್ಜಿಸಿ ವಿದ್ಯುತ್ ಸಂಪರ್ಕ ಕಲ್ಪಿಸಲಾಗುವುದು.
- 21. ಈ ಪತ್ರದಲ್ಲಿ ನಮೂದಿಸಿರುವ ಠೇವಣಿಗಳನ್ನು ಪಾವತಿಸಿದ ನಂತರ, ವೈರಿಂಗ್ ನಕ್ಷ, ಗುತ್ತಿಗೆದಾರರ ಸಮಾಪನಾ ವರದಿ ಮತ್ತು ಒಪ್ಪಂದ ಪ್ರತಿಗಳನ್ನು ಸಂಬಂಧಪಟ್ಟ ಉಪ–ವಿಭಾಗದಲ್ಲಿ ಸಲ್ಲಿಸುವುದು.
- 22. ಹೆಚ್ಚಿನ ಮಾಹಿತಿಗಾಗಿ **ಚಂದಾಮರ ವಿಭಾಗದ** ಕಾರ್ಯನಿರ್ವಾಹಕ ಇಂಜಿನಿಯರ್(ವಿ),ಜಿಗಡೆ ಉಪ–ವಿಭಾಗದ, ಸಹಾಯಕ ಕಾರ್ಯನಿರ್ವಾಹಕ ಇಂಜಿನಿಯರ್ (ವಿ) ಅವರನ್ನು ಸಂಪರ್ಕಿಸುವುದು.
- 23. ಸದರಿ ಸ್ಥಾವರಕ್ಕೆ ವಿದ್ಯುತ್ ಸಂಪರ್ಕ ಕಲ್ಪಿಸುವ ಸಂದರ್ಭದಲ್ಲಿ **KERC** ರವರ **clause-9** ರಸ್ವಯ ಹಾಗೂ KERC upto date Amendment ಗಳನ್ನಯ ಕ್ರಮ ಕೈಗೊಳ್ಳುವುದು.
- 24. ಭವಿಷ್ಯದಲ್ಲಿ, ಯಾವುದೇ ವ್ಯತ್ಯಾಸದ ಮೊತ್ತವು ಪಾವತಿಸಬೇಕಾದಲ್ಲಿ ಕೊಡಲೇ ಅದನ್ನು ಬೆವಿಕಂ ಗೆ ಪಾವತಿಸಬೇಕು.
- 25. ಸದರಿ ಗ್ರಾಹಕರು ಅನುಮೋದಿತ ನಕ್ಷೆಯ ಜೊತೆಗೆ ಹೆಚ್ಚುವರಿಯಾಗಿ ಮಹಡಿಗಳನ್ನು ನಿರ್ಮಿಸಿದ್ದರೆ, ಸದರಿ ಸಂಬಂಧವಾಗಿ ಯಾವುದೇ ಹೆಚ್ಚುವಳ ಮೊತ್ರದಂಡಕ್ಕೆ ಗ್ರಾಹಕರೇ ಜವಾಬ್ದಾರರಾಗಿರುತ್ತಾರೆ.

Page 3 of

Applicant Name: Smt. Lakshmi Reddy W/o Vijay Babu Reddy,

- 26. The released materials, if any as per 7th schedule credit estimate shall be handed over to the concerned divisional stores.
- 27. The materials used shall conform to the BESCOM Specifications, joint inventory should be submitted after completion of work.
- 28. Before execution of work the above mentioned License Electrical contractor has to obtain consent letter from the AEE (Ele) of the concerned sub-division for execution of works taking up all the safety measures and the concerned section officer before issuing the **Line Clear** has to confirm the same with the AEE (Ele) of their respective sub-division & contractor.
- 29. Precommissioning report from cables from BESCOM authorities, shall be obtained for the newly laid cables under self execution works before connecting to the net work.
- 30. As per Govt Notification No. KERC/COS/DDD/1/2018-19/908. Bengaluru dated:-22.10.2019. In the conditions of supply of distribution licensees in the state of karanataka. 2006 after the existing clause 9.0, the following new clause shall be insertd, namely-

"9A.00-Applicable to Commercial/Residential Buildings (s)/Complex/MS Building (s) in Metropolition areas/Urban Development Authority Areas of all Cities/City Corporation areas in the state of karanataka where:

- a) The requestioned load is 250KW or More; or
- b) The built-up area of the building is more than 5,000 Square meters

The Owner/Promoter/Occupier of the above building shall also provide not less than two number of charging points capable of Charging Electric Vechicles, i.e four/three/two-wheeler with adequate space in such buildings.

- 31. 'As per the Circular No. BESCOM/GM(M&C)/DGM(M&C)/AGM-M1/2022-23/CYS-02 dt: 01.04.2022 The metering arrangement is mandatory w.e.f 01.04.2022 towards the consumer requisite load between 50KW to 150KW with LT metering cubicle having the specification and design as per the prototype approval comprising the following:
  - 01 No. of CT & PT operated 02s accuracy class meter with provision for check meter.
  - 03 Nos. of LT CTs of 0.2s accuracy class with burden of 2.5VA and secondary current 1A.
  - 03 Nos. of LT PTs of 0.2 accuracy class with burden of 5VA and ratio 440/ 3 /110 3 volts.
  - 01 No. of Modem.

02No. Test Terminal Block and a suitable bus bar.

## Note:

- Intimation shall be issued to consumers in the power sanction letter to purchase LT metering cubicle from BESCOM approved VENDORS only.
- All installations serviced with sanctioned load of 50KW to 150KW from 01.09.2021 to till
  date shall be replaced with the newly mentioned LT metering system as stated vide OM. OM
  No. BESCOM/GM(M&C)/DGM(M&C)/AGM-M1/2021-22/CYS-19 dt: 01.09.2021.

Page 4 of 5

Applicant Name: Smt. Lakshmi Reddy W/o Vijay Babu Reddy,

- As per the Circular No. BESCOM/GM(QS&S)/DGM 3/AGM 1/BC-11/2025 26/CYS-115 dt 25.09.2025 Modification for the CT ratios of LT Metering cubicle required for arranging power supply to the installations with requisite load of 50KW to 150KW.
- 32 "ನಿಗಮ ಕಛೇರಿಯ ಪತ್ರ ಸಂಖೈ: ಮುಶ್ರವ್ಯಣ)/ಉಶ್ರವ್ಯ-3/ಬಸಿ-05/ಕ-341/25-26/CYS -02 ದಿನಾಂಕ 04-04-2025 ರ ಪ್ರಕಾರ ಎಲ್ಲಾ ಕ್ಷೇತ್ರಾಧಿಕಾರಿಗಳು ಮಾನ್ಯ ಘನ ಸರ್ವೋಚ್ಚ ನ್ಯಾಯಾಲಯದ ಸಿವಿಲ್ ಆಪೀಲ್ ಸಂಖೈ: 14604/2024 ಮತ್ತು 14605/2024 ದಿನಾಂಕ: 17.12.2024 ರಲ್ಲಿ ನೀಡಿರುವ ತೀರ್ಮ/ಆದೇಶವನ್ನು ಯಧಾವತ್ರಾಗಿ ಪಾಲಿಸುವುದು"

Note: For any 765/400/220/66/11 KV lines passing adjacent/nearby/on the premises, mandatory clearance certificate should be obtained from the competent authority by the developer / concerned EE of BESCOM before servicing of the installation. In case of any deviation in this regard concerned officers will be held responsible.

ಅಧೀಕ್ಷಕ ಇಂಜಿನಿಯರ್(ವಿ),

## ಪತಿಗಳನ್ನು:

- ಕಾರ್ಯನಿರ್ವಾಹಕ ಇಂಜಿನಿಯರ್(ದಿ), ಬೆರಿಕಂ, ಸಿಒಪಿಎಂ ಚಂದಾಮರ ವಿಭಾಗ ಇವರ ಮಾಹಿತಿಗಾಗಿ ಮತ್ತು ಸೂಕ್ತ ಕ್ರಮಕ್ಕಾಗಿ ಕಳುಹಿಸಲಾಗಿ:
- ಸಹಾಯಕ ಕಾರ್ಯನಿರ್ವಾಹಕ ಇಂಜಿನಿಯರ್(ವಿ), ಜೆವಿಕಂ, ಸಿಒಪಿಎಂ ಜೆಗಡೆ ಉಪ-ವಿಭಾಗ ಇವರ ಮಾಹಿತಿಗಾಗಿ ಹಾಗೂ ತಾವು ಹಣ ಪಾವತಿಸಿದ ದೃರ್ಧಿಕರಣದ ಪತ್ರವನ್ನು ನೇರವಾಗಿ ಈ ಕಛೇರಿಗೆ ಸಲ್ಲಿಸುವುದು.
- ಕಾನಿಇಂ(ಕ)/ಸಕಾನಿಇಂ(ಕ)/ಮು.ಖ್ಯ ಕಡಕಕ್ಷೆ.

Page 5 of 5

Applicant Name: Smt. Lakshmi Reddy W/o Vijay Babu Reddy,

AFEJIGANI (AET)

Office of the Assistant Executive Engineer Ele., C,O&M, JIGANI Sub Division BESCOM, JIGANI

To SRLLAXMI R REDDY SAKALAWARA-S/O.RAMAIAH REDDYSAKALAWARA-0

## Sir/Madam

Sub: Arranging power supply to an extent of 82.00 KW in favor of SRI.LAXMI R REDDY SAKALAWARA-S/O.RAMAIAH REDDYSAKALAWARA-0 in JIGANI OMU, JIGANI

Ref: 1) Your application registration 61324108250017 dated 11-AUG-2025

2) AEE/JIGANI /AE(T) a/ 27-OCT-2025

With reference to your application dated 11-AUG-2025. Requesting for arranging power supply to an extent of 82.00 KW power installations in favor of SRLLAXMI R REDDY SAKALAWARA-S/O.RAMAIAH REDDYSAKALAWARA-0 in JIGANI OMUJIGANI Sub division in hereby sanctioned subject to the following Conditions.

a. You are requested to pay the following charges by DD/cash (above 10000/- only DD will be Accepted) payable at the Office of C, O&M JIGANI sub-division and furnish the payment certificate for taking further action in this matter.

Application No	Sub Application No	Tariff	Requested Load	Account Head	Amount(Rs.)
61324108250017	2104232	LT3A-Rural- COMMERCIAL POWER & LIGHTING - LT3- RLB	82.00 KW	61.9067-LT METERING CUBICAL TESTING CHARGES	4080
61324108250017	2104232	LT3A-Rural- COMMERCIAL POWER & LIGHTING - LT3- RLB	82.00 KW	61,9067-61,9067-TRANSFORMER TESTING FEE	1000
61324108250017	2104232	LT3A-Rural- COMMERCIAL POWER & LIGHTING - LT3- RLB	82.00 KW	61.9047-( WITH TAX ) 5% Supervisory Charge(61.904)+CGST(46.9977)9%+SGST(46.9987)9%= (35265 + (35265*0.09) + (35265*0.09))	41613
61324108250017	2104232	LT3A-Rural- COMMERCIAL POWER & LIGHTING - LT3- RLB	82.00 KW	48.1037-48.1037 - ASD	108120
Total Amount in Rupees					

- b. The power supply will be arranged at 0V.
- c. The Tariff applicable to your installation will be LT3A-Rural, or the Tariff in force From time to time.
- d. You have to enter into an agreement with the BESCOM in the prescribed form.
- e. Submit the Contractor's Completion-Cum-Test Report along with diagram in Duplicate.
- f. You shall install LT metering panel approved by the BESCOM with suitable Capacity MCCB and/or ELCB.
- g. Energy meter should be placed outside the premises at the height of 5ft from the ground level.
- h. Amount through DD should be paid in the name AEE BESCOM JIGANI .
- i. Intimation is valid up to 30 days from the date of issue.