



BANGALORE ELECTRICITY SUPPLY COMPANY LIMITED

(Wholly owned Government of Karnataka Undertaking)

No. EEMT/AEE(O)/BRAZ/AEE HTR/ DPHT 189

To, The Asst. Executive Engineer (Ele), Add'n of Load

O&M Sub-Division. CD: 260 + 60 = 320 kVA

BESCOM, Melawangala

CTR: 20/1A

MC: 2000

Office of the Executive Engineer (Ele), MT Division, BRAZ, BESCOM, 3rd Floor, Crescent towers, Bangalore-560001.

Sir,

Date: 15/09/2025

Subject: Rating Report of HT/EHT Installation.

The H.T. Installation having the following details has been rated for periodical rating/complaint on 15/09/25. You are requested to take action on the observations and advice recorded in the report. Compliance report shall be sent to this office on the observations pointed out in the report. Details are furnished in the Annexure enclosed.

1. DETAILS OF H.T. INSTALLATION:

R.R. NO. DPHT 189 CD. 320 KVA CTR. 20/1A Previously rated on 21/06/2025 A Meter Constant. 2000
Activity..... Tariff. HT 2A (11)
Name & Address of the Consumer M/s. Veer 'O' Metals Pvt Ltd Plot Number E108 E11
4th phase, AVVetahalli, KRABR, Indl Area, Subbalepete.

2. OBSERVATION & ADVICE ON TECHNICAL MATTER:

The installation of the meter is calibrated before and after the replacement of CTR and found OK, and the meters are recorded with in the limit. Hence the serviced installation may be serviced duly.

3. ADVICE ON REVENUE MATTER:

Observing CTR update norms.
Ex. CD: 260 kVA New CD: 320 kVA
Ex. CTR: 15/1A New CTR: 20/1A modern: Nseqw 212420
Ex. MC: 1500 New MC: 2000

4. DOWNLOADED DATA ANALYSIS ENCLOSED: YES/NO.

Summary of analysis, if rated against complaint:

ANNEXURE

1. DETAILS OF SEALS:

R.R. No. DPHT 189

SL. No.	Seals Provided to	Sl. No. of Seals Found Plastic		Sl. No. of Seals Left Plastic	
		Main Meter	Check Meter	Main Meter	Check Meter
1	M.C. of Meter		BM 139945		
2	TC Of Meter		BRA 2B 21097		
3	M.D. Reset Knob		BRA 2B 21098, BRA 2B 88447		
4	Optical Port				
5	T.T.B		BRA 2B 23702, BRA 2B 88448		
6	Meter Chamber Main Door		BRA 2B 23703, BRA 2B 88449		
7	Meter Reading Window				
8	C.T./P.T. Chamber		BRA 2B 21101, BRA 2B 88450		
9	Cable Entry Chamber		BRA 2B 21102, BRA 2B 88451		
10	Hologram		MT 102904		

2. DETAILS OF THE EQUIPMENTS:

- a) Cubicle Type : Cable Entry / 6 bushing / 3 busing / LBS. Make..... Sl. No.....
b) Cubicle Conditions & Location..... Good.....

3. MULTIPLYING CONSTANT (MC) FOR BILLING (Kwh. Kvah. Kva) :

$$MC = \frac{PT \text{ Ratio} \times CT \text{ Ratio} \times \text{Dial Constant}}{\text{Meter PT Ratio} \times \text{Meter CT Ratio}} = \frac{11KV/\sqrt{3}/110/\sqrt{3} \times 20/1}{1 \times 1} \times 1 = 2000$$

4. DETAILS OF Ct's/ Pt's:

Two Thousand only.

