



BANGALORE ELECTRICITY SUPPLY COMPANY LIMITED

(Wholly owned Government of Karnataka Undertaking)

18

No. EEMT/AEE(O)/BRAZ/AEE HTR/

To,

The Asst. Executive Engineer (Ele),

O&M Sub-Division,

BESCOM... Dabarpeta...

Office of the

Executive Engineer (Ele),

MT Division, BRAZ, BESCOM,

3rd Floor, Crescent towers,

Bangalore-560001.

Sir,

MC: 3500

Date: 29/09/2015

Subject: Rating Report of HT/EHT Installation.

The H.T. Installation having the following details, has been rated for periodical rating/complaint on 29/09/15. You are requested to take action on the observations and advice recorded in the report. Compliance report shall be sent to this office on the observations pointed out in the report. Details are furnished in the Annexure enclosed.

1. DETAILS OF H.T. INSTALLATION:

R.R. NO. DPHT023 CD 700 KVA KVA CTR 35/1A Previously rated on 29/04/2015

Activity..... Tariff..... HTDA A Meter Constant..... 3500

Name & Address of the Consumer: M/s. Eureka Window System Pvt. Ltd. Plot H 150 1st Stage, Souppura, KTADG, Indl. Area, Dabarpeta

2. OBSERVATION & ADVICE ON TECHNICAL MATTER:

The installation of the meter is calibrated before and after the replacement of CTs and found O.K. And the meters are records with in the limit. The installation may be serviced duly observing corporate norms.

3. ADVICE ON REVENUE MATTER:

Ex CD: 600 KVA

Ex MTR: 30/1A

Ex MC: 3000

New CD: 700 KVA

New CTR: 35/1A

New MC: 3500

Model: NSeqw 7.0.1109

4. DOWNLOADED DATA ANALYSIS ENCLOSED: YES/NO.

Summary of analysis if rated against complaint.

ANNEXURE

1. DETAILS OF SEALS:

R.R. No. DPHT023

SL. No.	Seals Provided to	Sl. No. of Seals Found Plastic		Sl. No. of Seals Left Plastic	
		Main Meter	Check Meter	Main Meter	Check Meter
1	M.C. of Meter				
2	TC Of Meter				
3	M.D. Reset Knob				
4	Optical Port				
5	T.T.B				
6	Meter Chamber Main Door				
7	Meter Reading Window				
8	C.T./P.T. Chamber				
9	Cable Entry Chamber				
10	Hologram				

2. DETAILS OF THE EQUIPMENTS:

a) Cubicle Type : Cable Entry / 6 bushing / 3 busing / LBS. Make..... Sl. No.....

b) Cubicle Conditions & Location: Good

3. MULTIPLYING CONSTANT (MC) FOR BILLING (Kwh, Kvah, Kva) :

$$MC = \frac{PT \text{ Ratio} \times CT \text{ Ratio} \times \text{Dial Constant}}{\text{Meter PT Ratio} \times \text{Meter CT Ratio}} = \frac{110V/\sqrt{3}/110/\sqrt{3} \times 35/1 \times 1}{1 \times 1} = 3500$$

4. DETAILS OF Ct's/ Pt's:

Three thousand Five Hundred only.

