



BANGALORE ELECTRICITY SUPPLY COMPANY LIMITED

34

(Wholly owned Government of Karnataka Undertaking)

No. EEMT/AEE(O)/BRAZ/AEE HTR/

To,
The Asst. Executive Engineer (Ele),
O&M Sub-Division,
BESCOM, Maluramangala

Office of the
Executive Engineer (Ele),
MT Division, BRAZ, BESCOM,
3rd Floor, Crescent towers,
Bangalore-560001.

Sir,

Red'n of Load 65 kVA
CTR: 10/1A
MC: 1000

Date: 22/09/2025

Subject: Rating Report of HT/EHT Installation.

The H.T. Installation having the following details has been rated for periodical rating/complaint on 22/09/2025. You are requested to take action on the observations and advice recorded in the report. Compliance report shall be sent to this office on the observations pointed out in the report. Details are furnished in the Annexure enclosed.

1. DETAILS OF H.T. INSTALLATION:

R.R. NO. 0PHT 188 CD. 18.5 KVA KVA CTR. 10/1A Previously rated on 23/05/2025
Activity..... Tariff..... A Meter Constant..... 1000
Name & Address of the Consumer M/S. Calcutta Depot, Sampurva, 2nd Stage
KIADB, Indl. Area, Thymagandla

2. OBSERVATION & ADVICE ON TECHNICAL MATTER:

Installation of the meter is rated and found that the meter one reads OK. The meter one calibrated before and after the replacement of CT's and found OK. The existing CT's are good condition. The installation may be serviced duly observing corporate norms.

3. ADVICE ON REVENUE MATTER:

Ex. CD: 250 KVA
Ex. CTR: 12.5/1A
Ex. MC: 1250
New CD: 250-65 = 185 KVA
New CTR: 10/1A
New MC: 1000
Maluram: 22/09/2025

4. DOWNLOADED DATA ANALYSIS ENCLOSED: YES/NO.

Summary of analysis if rated against complaint.....

ANNEXURE

1. DETAILS OF SEALS:

R.R. No. 0PHT 188

SL. No.	Seals Provided to	Sl. No. of Seals Found Plastic		Sl. No. of Seals Left Plastic	
		Main Meter	Check Meter	Main Meter	Check Meter
1	M.C. of Meter		BM3 08105		
2	TC Of Meter		BR12B 71441		
3	M.D. Reset Knob		BR12B 71442, BR12B 88721		
4	Optical Port				
5	T.T.B		BR12B 73421, BR12B 88722		
6	Meter Chamber Main Door		BR12B 73422, BR12B 88723		
7	Meter Reading Window				
8	C.T./P.T. Chamber		BR12B 71445, BR12B 88724		
9	Cable Entry Chamber		BR12B 71446, BR12B 88725		
10	Hologram		MT103593		

2. DETAILS OF THE EQUIPMENTS:

- a) Cubicle Type : Cable Entry / 6 bushing / 3 busing / LBS. Make..... Sl. No.....
b) Cubicle Conditions & Location..... Good.....

3. MULTIPLYING CONSTANT (MC) FOR BILLING (Kwh. Kvah. Kva) :

$$MC = \frac{PT \text{ Ratio} \times CT \text{ Ratio} \times \text{Dial Constant}}{\text{Meter PT Ratio} \times \text{Meter CT Ratio}} = \frac{11kV/\sqrt{3}/110/\sqrt{3} \times 10/1 \times 1}{1 \times 1} = 1000$$

4. DETAILS OF Ct's/ Pt's:

One thousand only.

