



**GOVERNMENT OF KARNATAKA  
(Electrical Inspectorate)**



Scan the above QR Code  
for verifying the authenticity of the Approval

EI000110877707

Date : 13/10/2025

O/o. Deputy Chief Electrical Inspector,  
Bangalore West,  
No. 129, 1st Floor, 3rd cross,  
Subramanya Bharathi Road, Gavipuram Extension,  
Hanumanth nagar, Bangalore-560019.  
Phone No :080-26612080

RI. GOVINDAIAH

Sy. No. 127/1/11, M/s THIRUMALA ENTERPRISES, BENNAYAKANAHALLI VILLAGE, KASABA HOBLI  
TIPTUR TALUK TUMKUR DIST, TUMAKURU(District), TIPTUR(Taluk)  
Karnataka, India - 572201

Approval of Drawing pertaining to the Electrical Installation- 1x1000 KVA, 11/0.433 KV transformer and connected equipments  
for arranging HT power supply to an extent to 600 KVA at **SRI. GOVINDAIAH** Sy. No. 127/1/11, M/s THIRUMALA ENTERPRISES,  
BENNAYAKANAHALLI VILLAGE,, KASABA HOBLI, TIPTUR TALUK TUMKUR DIST, TUMAKURU(District), TIPTUR(Taluk) - 572201

Acknowledgement No.EI000110877707 for requesting drawing approval

\*\*\*\*\*

**Note :**

Necessary permissions shall be obtained from the licensing authority and KSPCB

Please find here in the drawings duly approved after effecting necessary corrections and with observations noted in **RED INK**.  
You may take up the work through a Licenced Electrical Contractor as per the approved drawings and after completing the work,  
submit the connected documents with completion report to the **undersigned** along with the following particulars to arrange for  
inspection.

This Approval is valid only for a period of **TWENTY FOUR MONTHS** only from the date of approval and extension may be  
obtained separately for a further period of Twelve Months only as per sub rule (5) Rule 7 of The Karnataka Electrical Inspectorate  
(Power, Functions and levy of fees) Rules, 2018.

**PARTICULARS OF HT/DG:**

1. Manufacturers Test Reports of Generator / Transformer / HT / LT breakers etc.,
2. Completion report of Licensed Electrical Contractor for having completed the works as per the approved drawings along  
with the following details.
  - a) Description of the motor/equipments, indicating serial numbers.
  - b) Rating in HP/KW/KVA
  - c) Feeder details
  - d) Voltage Rating, insulation test results of the equipments.
  - e) Earth Test Results.
  - f) The completion report should be signed by the Licenced Electrical Contractor and the Electrical supervisor along with  
their valid licence / Permit number and validity date.
3. Oil Test Results of transformer/oil circuit breaker.
4. Insulation test results of transformer/ generator OCB's cable and other connected equipments.
5. Calibration certificates in original of protective devices, CTs, PTs, Energy meters etc., as calibrated by the relay testing and  
meter testing division of KPTCL and other approved agencies.



**GOVERNMENT OF KARNATAKA  
(Electrical Inspectorate)**



Scan the above QR Code  
for verifying the authenticity of the A

6. Earth test results of all the earth electrodes disconnecting all the earth leads from them.  
7. A List of authorized persons qualified to operate at the sub-station/ at the works ( list shall be signed by both the employees and employer with permit number and validity date)

Challan/Receipt for having paid **Rs. 20,500 /-** (IN WORDS) **Twenty Thousand Five Hundred only** towards inspection charges under the following Budget Head Non-Plan 0043-00-102-0-01 other taxes and duties on Electricity through E-payment only.

Drawing Scrutiny Fees of Rs. **2,600/-** (IN WORDS) **Two Thousand Six Hundred only** paid vide K2 Challan Ref **EL0925004300009876** dated **15/09/2025** is hereby acknowledged.

Yours faithfully,



**Note: This is a Digitally Signed Certificate  
and Does not require manual signature.**

**Please, Verify authenticity of this certificate  
by visiting [www.ksei.gov.in](http://www.ksei.gov.in) and entering  
certificate number in Third party  
verification.**

**Digitally Signed by : HAADLAHALLY NAGANNAGOWDA  
HEMANTHAKUMAR**

**Deputy Chief Electrical Inspector  
Bangalore West**

**Signed Date**

**: 13/10/2025**

**Copy To : ESHWARI ELECTRICALS  
#18, RAMESHWARA NILAYA , KATTIGENHALLI ROAD , K.B CROSS , BEHIND MAYURA HOTEL , TIPTUR TALUK  
TUMKUR DIST , TUMAKURU , 572114  
License No: 1CL12708TKR - Valid Upto: 31/01/2026**