



# Bangalore Electricity Supply Company Limited

(Wholly owned by Government of Karnataka Undertaking)

No: EEE/HKTD/AEE (O)/AE(T)/2023-24/ 12362

Office of  
Executive Engineer  
C, O&M BESCOM

To  
**EAST POINT COLLEGE,**

Bidarahalli Village,  
Rep by Sri.Munishamappa Gowramma,  
Charitable Trust,  
Bidrahalli Hobli,  
Banglore East Taluk

Sir/Madam,

Sub: Arranging power supply to an extent of **Addl Load of 150 KVA** to the existing contract demand 200 KVA total 350 KVA bearing RR No.HKHT-221 in favour of **East Point Collage** educational Pvt, Rep by Sri.Munishamappa Gowramma, Charitable Trust, **Bidarahalli Village**, Bidrahalli Hobli, Bangalore East Taluk in Avalahalli O&M of Avalahalli Subdivision Under self execution.

Ref: 1)Your Application Reg. No. 8311222 dated:01/03/2024.  
2) Letter No:AEV/AVL/AET/2023-24/7882 dt.06.03.2024.

BESCOM is pleased to sanction for power supply to an extent of Addl Load of 150 KVA to the existing contract demand 200 KVA total 350 KVA bearing RR No.HKHT-221 in favour of East Point Collage educational Pvt, Rep by Sri.Munishamappa Gowramma, Charitable Trust, Bidarahalli Village, Bidrahalli Hobli, Bangalore East Taluk in Avalahalli O&m of Avalahalli Subdivision Under self execution.

Subject to below conditions:

#Error

2.You are requested to pay the following charges by DD/Cash ( above 10000/- only DD will be accepted ) payable at the office of the Asst. Executive Engineer (C,O&M), BESCOM AVALAHALLI Sub-Division within 90 Days from the date of its intimation and furnish the payment certificate for taking further action in this matter

Payment Towards	Amount(Rs.)
2 mmd	360000.00
5% Supervisory Charge(61.904)	2157.00
CGST 9% on 5% Supervisory Charge	194.00
SGST 9% on 5% Supervisory Charge	194.00
Total	362545.00

3. To Submit payment certificate along with Self execution agreement on Rs. 200/- stamp paper regarding obtaining of necessary line clearance from field staff for safe execution of works & to comply with all safety procedure duly using safety equipment's during the course of work after which a works certificate / permit will be issued to take up the works on Self execution basis.  
4. The metering equipment to be installed should be conspicuously visible and at the main inference to the premises preferably with an independent entrance.  
5. You should own and install the necessary transformer at your end to receive and step it down to the required distribution voltage for your installation  
6. It is proposed to provide CT's with HT ETV Meter 1A class 0.2s accuracy with TOD feature 3CT's 3PT's metering cubicle.  
7. a) You should execute an agreement in the prescribed form and shall be submitted to the Executive Engineer Ele. of concerned division along with payment certificate.  
8. Produce necessary Licensee/permit/NOC objection Certificate, etc. issued by the competent authorities as required under statute.

**BANGALORE ELECTRICITY SUPPLY COMPANY LIMITED****(Wholly Owned Government of Karnataka Undertaking)**

NO : EEE/HKTD/AEE(O)/AE-1/2025-26/309475

Date : 3/7/25

Encl:

O/o Executive Engineer (Elec),  
C, O&M Hoskote Division,  
Hosakote-562114.Email ID: eehosakotedivision@bescom.co.in  
eeylhmk.work@gmail.com

☎: 080-27931033 / 9448279024

**OFFICIAL MEMORANDUM****Sub:** Additional load from 200 kVA to 350 kVA of existing HT installation bearing RR No. HKHT-221.**Ref:** AEE/AVL/AE(T)/25-26/1354 Dt: 23.06.2025.


\*\*\*\*\*

Approval is hereby accorded for HT load enhancement change for the installation bearing Account ID - 2261369 as desired vide Application No. 8311222 (RR No. HKHT221, Existing load: 200 KVA, Additional load: 150 KVA, Total load: 350 KVA, Avalahalli O&M unit of Avalahalli sub division) requested from Monthly 200.00 KVA tariff schedule for Normal customers to 350.00 KVA load enhancement over online by the consumer.

It is communicated that the existing load for the Account ID. 2261369 has been changed in our records from Monthly 200.00 KVA load schedule for Normal customers to 350.00 KVA load.

Also, East point College, Educational Institution Pvt Charitable Trust are liable to pay the short claim amount, if any noticed at a later date including for the period prior to the HT load enhancement of the installation.

The HT load enhancement change takes effect on the next reading date.

**Executive Engineer, El., (C, O&M),  
BESCOM, Hosakote Division.****Copy to:**

1. Assistant Executive Engineer(Ele), BESCOM., Avalahalli Sub-Division for information.
2. Accounts Officer / Accounts Officer (I/A), Hosakote Division for information.
3. The Section Officer, Avalahalli O&M unit.
4. East point College, Educational Institution Pvt Charitable Trust. at No. 1471/1, Bidarahalli Village, Bangalore East Taluk.
5. MF / R&R AE - 1.