




BANGALORE ELECTRICITY SUPPLY COMPANY LIMITED
(Wholly owned by Government of Karnataka)

No. DEES/AEE(O)/AET(2)/Klr/2025-26/3426-27
Mobile No.9448279019
Phone No.08152 295116
Email id: eeklrdivn.work@gmail.com
Encl



Office of the
Executive Engineer (Ele)
C, O & M Division,
BESCOM, Kolar

Date: 10 JUL 2025

" Grant "

To,
Asst. Executive Engineer
RDWS & S sub-division,
Kolar.

1221106250028
Kolar

Sir,

Sub:	Power sanction for Arranging Power Supply of 20 HP to Water supply bore well at Beechagongahalli Village in Chennasandra Grama Panchayat on the request of AEE, RDWS & S sub-division under JJM scheme in Kyalanur Section of Kolar Rural Sub-division (Under self-execution)- reg.
Ref:	01. Submission of file from AEE Kolar Rural vide Letter no: AEE/AET/KRSD/2025-26/1390, Dated: 04.07.2025 02. Inward Letter No: 1690, Dated:05.07.2025. 03. Request letter of AEE, RDWS & S No: 117/2025-26 Dated:12.06.2025. 04. Online application registration application ID No. 1221106250028, Sub ID 12211062500280001, Dated: 16.06.2025 05. Estimate No. NVN/WS/343, Dated:25.06.2025.


BESCOM is pleased to communicate the Power sanction for Arranging Power Supply of 20 HP to Water supply bore well at Beechagongahalli Village in Chennasandra Grama Panchayat on the request of AEE, RDWS & S subdivision Kolar under JJM scheme in Kyalanur Section of Kolar Rural Sub-division (**Under self-execution**).

The Power Sanction is subject to the following conditions:

1. You shall construct 11 KV line, DTC and LT metering as per the BESCOM norms **under Self-Execution**.
2. The materials procured shall be in-accordance with the IE/BESCOM/KPTCL specifications and the materials shall be got inspected by QS & S / Jurisdictional Executive Engineer Ele, C, O & M Division BESCOM. The copies of the invoices / bills of the materials purchased shall be submitted as proof of purchase from the BESCOM approved vendors / dealers.
3. You have to pay the following amounts through DD Payable at SBI Kolar Rural branch, drawn in favor of AEE, BESCOM, Kolar Rural Sub-Division within 180 days from the date of this intimation and Electrical inspectorate charges to DEI, Govt. of Karnataka.
 - a. Rs. 13,108/- towards Supervision charges at 5% of estimate cost of Rs.2,62,151/-
 - b. Rs. 25,600/- towards ISD under LT-6(a) tariff for 20 HP.
 - c. Rs. 5,000/- towards Material Inspection Charges.
 - d. Rs. 1,000/- towards Transformer testing Charges.
4. You have to execute the works as per approved estimate under self-execution through class-1 Licensed Electrical Contractor, under the supervision of BESCOM.
5. You have to register your borewell at O/O the Senior Geologist, Geologist Dept, Kolar and obtain Geologist Certificate Form.5(A) and to submit the same without fail along with payment certificate.
6. The major materials like Transformer, ACSR conductor, Metering cubicle, HT UG cable etc., shall be procured from the BESCOM approved vendors and other materials may be procured from authorized dealers /approved vendors. You have to use only

- Polymer Insulators as per the corporate circular no. BESCOM/W-9/CIM(CA)/DCIM(CA-3)/P-752/13-14/CYB-113 dated 29-8-13.
7. Major materials like Transformers, RMUs, UG Cable, AB Cable, any insulated aluminum/copper conductor, Optical fiber, Insulators, GOS & CSS shall be assured guaranteed for 5 years for the defects in materials and workmanship from the date of commissioning.
 8. Minimum guarantee of five years from the date of commissioning for the materials like Transformers, RMUs, UG Cable, AB Cable, any insulated aluminum/copper conductor, Optical fiber, Insulators, GOS & CSS. For the rest of equipment's/materials shall be guaranteed for the 12 months from the date of commissioning. The consumer liability shall be limited to the replacement of the any defective parts in the equipment's of his own manufacture or those of his vendors.
 9. Guarantee for period not less than one year for the quality of work carried out from the date of taking over the lines and equipment's by BESCOM.
 10. **Approval of the Electrical Inspectorate shall be obtained for the electrical equipment and lines before Commissioning as per the KERC norms.**
 11. BESCOM is not responsible in whatsoever manner regarding any legal disputes that may arise at a later stage.
 12. Any modification in the existing system shall be at the cost of developer with prior approval of the competent authority. Suitable safety clearance shall be maintained for the Electrical lines in accordance with the IE rules.
 13. NOC from concerned authority (PGCIL/KPTCL) shall be obtained whenever EHV lines pass in the premises.
 14. You should clear the outstanding arrears of the installations inside the premises, if any.
 15. You should abide to the conditions of supply as per prevailing electricity act in force with subsequent amendments.
 16. As per the KERC clause 4.02(g)(iv) & amendment No. KERC/COS/D/07/10, Dtd.01.07.2010 you have to install Solar water heaters & same shall be certified & to be produced before servicing the installation.
 17. You have to purchase necessary meter and CT's from approved vendor at your own cost as per current norms of KERC/BESCOM.
 18. An under taking letter stating that you will not engage child labor in your industry as per child labor (prohibition and regulation) act 1986.
 19. The payment certificate duly signed by the Assistant Executive Engineer, Kolar Rural Sub-Division shall be sent to this office for issuing Administrative approval. Any delay in making payment, not fulfilling the above conditions within 180 days, the power sanction is deemed to be cancelled as per the conditions stipulated in the KERC.
 20. You have to pay any variation / difference charges payable to BESCOM, if any in future.
 21. You are requested to contact the Assistant Executive Engineer, El., C, O & M Kolar Rural, for any clarifications.

Yours faithfully,


Executive Engineer, El.,
C, O & M Division,
BESCOM, Kolar

Copy to:-

1. The Asst. Executive Engineer (Ele), C, O & M Kolar Rural Sub-Division, BESCOM, Kolar.
2. AEE(O)/AE-2/OC/MF.